



# Operational flexibility and economics of power plants in future low-carbon power systems



Anne Sjoerd Brouwer<sup>a,b,\*</sup>, Machteld van den Broek<sup>a</sup>, Ad Seebregts<sup>b</sup>, André Faaij<sup>a,c</sup>

<sup>a</sup> Copernicus Institute for Sustainable Development, Utrecht University, Heidelberglaan 2, Utrecht, The Netherlands

<sup>b</sup> Energy Research Centre of the Netherlands (ECN), Radarweg 60, Amsterdam, The Netherlands

<sup>c</sup> Energy Sustainability Research Institute Groningen, University of Groningen, Nijenborgh 4, Groningen, The Netherlands

## HIGHLIGHTS

- Key flexibility parameters of current and future thermal power plants are quantified.
- Four power mix scenarios are designed and simulated with flexibility constraints.
- Low-carbon scenarios need more flexibility; which power plants can deliver.
- Power plant efficiency is reduced by variable residual load, not only renewables.
- The current market design only covers 84% ( $\pm 30\%$ ) of total power costs per MWh.

## ARTICLE INFO

### Article history:

Received 12 February 2015

Received in revised form 19 June 2015

Accepted 23 June 2015

Available online 10 July 2015

### Keywords:

Flexibility

Thermal power plants

Renewable energy

Power system modeling

Carbon Capture and Storage

## ABSTRACT

Future power systems will require large shares of low-carbon generators such as renewables and power plants with Carbon Capture and Storage (CCS) to keep global warming below 2 °C. Intermittent renewables increase the system-wide demand for flexibility and affect the operation of thermal power plants. We investigate the operation of future power plants by first composing a comprehensive overview of the operational flexibility of current and future power plants. Next, a combined long-term optimization and hourly simulation is performed with the soft-linked MARKAL-NL-UU and REPOWERS models for The Netherlands in 2030 and 2050. We quantify and compare the technical and economic performance of power plants for four distinctly different future scenarios. We find that future low-carbon power systems will have large shares of intermittent renewable sources (19–42%) and also a 2–38% higher variability in residual load compared to the Baseline scenario. Hence, power plant operation will be more variable, which reduces their efficiency by 0.6–1.6% compared to the full-load efficiency. Enough flexibility is present in future power systems to accommodate renewables, due to advances in power plant flexibility and interconnectors. As a result, generators with CCS have a large market share (23–64% of power generated). Moreover, the current energy-based market model generates insufficient revenues: the price received per MWh covers only 84% ( $\pm 30\%$ ) of the total generation costs per MWh of 77 €/MWh ( $\pm 12\%$ ). This will discourage new investments in generation capacity and reduce power system adequacy. New or additional market designs may be required to ensure system adequacy in future power systems.

© 2015 Elsevier Ltd. All rights reserved.

*Abbreviations:* ASU, Air Separation Unit; CF, capacity factor; CCS, Carbon Capture and Storage; ECN, Energy research Centre of The Netherlands; ECF, European Climate Foundation; EU, European Union; FOM, fixed operation and maintenance; HRSG, heat recovery steam generator; IGCC, integrated gasification combined cycle; IEA, International Energy Agency; IRES, intermittent renewable energy sources; GT, gas turbine; LHV, lower heating value; NGCC, natural gas combined cycle; PBT, pay back time; PC, pulverized coal; PV, photovoltaic; RES, renewable energy sources; SR, spinning reserve; SRP, short run profit; UCED, unit commitment and economic dispatch.

\* Corresponding author at: Heidelberglaan 2, 3584CS Utrecht, The Netherlands.

E-mail address: [a.s.brouwer@uu.nl](mailto:a.s.brouwer@uu.nl) (A.S. Brouwer).

## 1. Introduction

In order to mitigate the adverse effects of climate change, the European Commission has proposed to deeply reduce European Union greenhouse gas emissions by 40–44% by 2030 and 80–95% by 2050 compared to 1990<sup>1</sup> [1,2]. The largest emission reductions

<sup>1</sup> Emission of greenhouse gasses amounted to 5.6 Gtonne CO<sub>2</sub>-eq in the EU-28, excluding land use change emissions [143].

are projected for the power sector: reductions of 54–68% by 2030 and 93–99% by 2050 compared to 1990 [1]. The transition to such low-carbon power systems will require a shift to low-carbon generators such as renewable energy sources (RES), nuclear power plants and generators with Carbon Capture and Storage (CCS) [3–5].

The new low-carbon generator mix may affect the technical and economic workings of the power system. From a technical perspective, the system could run out of flexibility: intermittent RES require flexibility from the power system, whilst coal fired power plants (which are likely candidates for CCS), and nuclear power plants are relatively inflexible [6,7]. Moreover, intermittent RES may slightly reduce the efficiency of power plants [8]. From an economic perspective, intermittent RES may reduce the profitability of nuclear plants and generators with CCS by decreasing their capacity factor and lowering wholesale electricity prices. Moreover, the profit of these thermal power generators is reduced by lower electricity prices through the *merit order effect* [9] and lower capacity factors of thermal power generators. As stated by the IPCC SRREN report: “combined integration of IRES and IGCC/CCS or nuclear may pose special integration challenges” [10].

Few studies have explicitly looked at the technical (i.e. flexibility) and economic feasibility of multiple long-term low-carbon scenarios, and the differences between them. Five studies looked at low-carbon energy systems with flexibility constraints of 2030 and beyond. Two studies of these considered the future EU energy system at large. The Roadmap 2050 study by the European Climate Foundation (ECF) found that “capacity factors of nuclear and coal plus CCS remain high throughout the year,” and that reduced generator flexibility has small impacts, but without providing details about power system operation [3]. The European Commission ordered a study on low-carbon energy scenarios for the EU, which does not specifically mention flexibility constraints, and only reports aggregated outcomes [4]. Bertsch et al. studied a future European low-carbon power system with a 80% RES penetration by 2050. They concluded that flexibility will largely be provided by gas turbines, and that operation of nuclear power and generators with CCS will break even [11,12]. Cohen studied the operation of power plants with CCS in detail for the Texas power system, but only considered wind penetrations up to 20% [13]. Lastly, Hundt et al. studied the effect of nuclear power plant lifetime extension on the 2030 German power system with 40–50% RES, without accounting for CCS [14]. Moreover, a number of studies have investigated the role of CCS in future power systems with less detailed power system models, which have lengthy time slices (>1 day) and do not account for flexibility constraints e.g. [14,15].

Overall, these studies are either not explicit about the flexibility constraints that are used and the role of flexibility in the power system [3,4], or they do not consider fundamentally different scenarios: high levels of RES are commonly assumed as a starting point [11,13,14]. This study aims to fill this research gap by providing a consistent dataset on the flexibility of thermal power generators. Next, we perform a hourly simulation with these flexibility parameters, for four distinctly different scenarios with the REPOWERS model. These scenarios are calculated as part of this study with the MARKAL-NL-UU long-term optimization model. The goal of the study is to answer the main question “How flexible are future power plants, and how do they perform in future low-carbon electricity systems from a flexibility and an economic perspective?”

Part 2 describes the method and the two models that are used in this study. Part 3 presents the input data for these two models, and Part 4 shows the results. Part 5 and 6 contain the discussion and conclusion.

## 2. Methods

A comprehensive overview of flexibility parameters is first compiled as an input dataset. Next, four scenarios are defined. Lastly, we describe the combined MARKAL-NL-UU and REPOWERS models, which model the four scenarios to assess the technical and economic operation of power plants in distinctly different future power systems.

### 2.1. Flexibility parameters

Data on the current and future flexibility of power plants were collected from equipment manufacturers, gray literature and scientific articles, and confirmed with 5 experts. We provide the typical values, as well as the range that is provided in literature (Table 3). Whenever little or no information is available for the 2020 and 2030 cohorts, we extrapolate the 2000 and 2010 data if literature mentions that specific improvements are available. A detailed description of power plant flexibility is provided in Appendix B.

### 2.2. Scenarios

Four scenarios are considered in this study: Baseline, Stalemate, Global Union, and Fuel Shift, based on Van den Broek et al. [16]. The four scenarios were updated in this study based on recent scenarios [3–5,17]. These scenarios are chosen because they explore a range of different climate action policies (Table 1). The study focusses on the Netherlands, because it has a diverse, modern power system with the potential for large shares of IRES, and modern coal fired power plants that can be equipped with CCS [18].

Long term projections of the electricity demand in the Netherlands show annual growth rates that range from 0.3% to 1.1% per year, depending on end-use efficiency and electrification of transport and heat. Based on the shared trends shown by other studies, electricity demand increases by 1.0% per year for the Baseline scenario, of 0.8% per year for the Stalemate and Global Union scenarios, and of 0.45% for the Fuel Shift scenario [3,4,17].

CO<sub>2</sub> prices are calculated with the MARKAL model for the Netherlands based on European CO<sub>2</sub> emission reduction targets. Predetermined CO<sub>2</sub> prices are only used in the Fuel Shift scenario to simulate the effect of high CO<sub>2</sub> prices. Overall, a range of CO<sub>2</sub> price levels is considered (0–195 €/tCO<sub>2</sub> across the scenarios) (Table 6), which reflects the large uncertainty in CO<sub>2</sub>-price projections [19].

All costs are expressed in €<sub>2011</sub> based on historical exchange rates and the European Power Capital Cost Index [20,21]. Fuel prices are adopted from the World Energy Outlook 2012, because these long-term projections align well with the scenarios of this study (Table 2) [5]. CO<sub>2</sub> transport and storage costs are estimated at 6 €/tCO<sub>2</sub> and 8 €/tCO<sub>2</sub> respectively for future deployment of CCS in the Netherlands with a large CO<sub>2</sub> transportation network and storage offshore in depleted oil and gas fields [22].

### 2.3. Models

Two soft-linked models are used to simulate the dispatch of power plants in the Dutch power sector for four electricity mix scenarios. Input data and model properties are summarized in Fig. 1. First, future power plant portfolios and CO<sub>2</sub> prices are calculated with the MARKAL-NL-UU optimization model for each scenario, whilst optimizing for the lowest cost. Next, these generator portfolios are simulated in more detail with the REPOWERS unit commitment and economic dispatch power system model, which accounts for flexibility constraints. In the post analysis step, the outcomes of

**Table 1**  
Description of scenarios considered in this study.

Scenario	Scenario description	Electricity demand increase (% yr <sup>-1</sup> )	2050 Dutch power sector CO <sub>2</sub> emissions
Baseline	This scenario is based on estimates of current trends, and only includes policies that were adopted by 2012. As such, it resembles the Current Policies scenario used by the IEA [5], the Reference case of the European Commission [4] and the Business as Usual scenario of ECN [17]. According to this Baseline, no additional governmental action is taken to curb CO <sub>2</sub> emissions. Moreover, energy demand increases rapidly, which is largely supplied from fossil fuels	1	No cap
Stalemate	The Stalemate scenario assumes that the developed and developing countries that emit most CO <sub>2</sub> fail to reach post-2012 climate agreements. This leads to a “stalemate”: no follow-up agreements are made to curb CO <sub>2</sub> emissions, and the 2 degree target is not met. The EU maintains its emission trading system, hoping that it may encourage future global climate action, and because it will allow for quick implementation of stringent reduction targets if climate action is taken. Toward the middle of the century, the effects of climate change prompt the EU to reduce its carbon emissions to 40% of 1990 levels	0.8	16 Mton cap (60% reduction compared to 1990)
Global Union	The Global Union scenario assumes ‘ideal’ development of climate policies, with international climate negotiations reaching an agreement that not just includes the OECD countries, but also large, fast-growing developing countries such as China, India and Brazil. The new climate agreement aims to limit global warming to less than 2 °C, which leads to a large switch from fossil to renewable energy sources	0.8	2 Mton cap (95% reduction compared to 1990)
Fuel Shift	The Fuel Shift scenario assumes similar political developments as in the Global Union scenario. Moreover, the Netherlands decide that the share of coal-fired electricity generation should be reduced for environmental and geopolitical reasons. This leads to a shift from coal to natural gas for electricity production, as biomass is used more cost-effectively in the transportation sector. As a result, the total electricity demand is lower in this scenario, and electricity is co-produced during the production of Fischer–Tropsch fuels	0.45	195 €/tCO <sub>2</sub>

**Table 2**  
Fuel prices used in this study.

	2030			2050 <sup>a</sup>		
	Coal (€/2011/GJ)	Natural gas (€/2011/GJ)	Biomass (€/2011/GJ) <sup>b</sup>	Coal (€/2011/GJ)	Natural gas (€/2011/GJ)	Biomass (€/2011/GJ) <sup>b</sup>
Baseline	3.4	8.9	8.0	3.8	9.7	9.0
Stalemate	3.1	8.1	8.0	3.3	8.5	9.0
Global Union, Fuel Shift	2.2	6.6	8.0	1.2	5.1	9.0

<sup>a</sup> Fuel prices were extrapolated for the years 2040–2050.

<sup>b</sup> Biomass pellet prices are based on conservative projections, as future developments are highly uncertain (3–9 €/GJ) [23–25].

the two models are compared to check if they are internally consistent, and performance parameters are calculated. In this study, the REPOWERS model is run for the years 2030 and 2050.

### 2.3.1. MARKAL model

The MARKAL (MARKet ALlocation) model is a bottom-up linear optimization tool (Appendix A). It calculates the optimal (least-cost) way to supply energy services based on available resources and a portfolio of energy conversion technologies [26,27]. The MARKAL-NL-UU model optimizes the Dutch energy system, as described in [16,28,29], and specifically the Dutch power sector in this study. A coherent input dataset was constructed based on public sources (Section 3, Appendix C). The model calculates the CO<sub>2</sub> price based on a predefined emission cap for the Netherlands.

### 2.3.2. REPOWERS model

The REPOWERS model is an unit-commitment and economic dispatch (UCED) simulation model for the Dutch power sector developed by the Energy Research Centre of The Netherlands (ECN) (Appendix A) [30]. The model optimizes the hourly commitment and dispatch of generation units based on their variable costs for a whole year. It accounts for flexibility, interconnection and spinning-reserve constraints. Input data are based on public sources (Section 3, Appendices C and D).

### 2.3.3. Soft linking the models

The MARKAL and REPOWERS models are soft linked according to the soft link method for the TIMES and PLEXOS models proposed

by Deane et al. [31]. This involves running the models sequentially with the same input parameters, where output from MARKAL serves as input for REPOWERS. The method of Deane et al. is adapted slightly: electricity demand is determined exogenously for both models, instead of being calculated by an optimization model, and we focus on the operation of power plants rather than the reliability of the power system. In addition, an extra step is required to define individual units from the more aggregated MARKAL output for REPOWERS.<sup>2</sup>

### 2.3.4. Post analysis

Four performance parameters are calculated in the post analysis.

- (1) The adequacy of hourly and sub-hourly standing reserves is evaluated by calculating the required reserve sizes, and the supply of these reserves by the available power plants in the scenario.
- (2) The efficiency reduction of thermal power generators is calculated by comparing their realized efficiencies with their nominal efficiency. Also, the average reduction in efficiency is calculated per scenario weighted to the power generation per power plant.

<sup>2</sup> Unit are defined based on pre-set sizes of 700 MW for PC, 650 for NGCC and 600 for IGCC are used, as they show the best conversion of MARKAL output to units for REPOWERS.




Fig. 1. Schematic overview of modeling toolbox used in this study.

(3&4) The annual Short-Run Profit (SRP) and the discounted payback time (DPT) are calculated to define the profitability of power plants [32]. They are based on the current power system market design, where generators are paid per MWh produced according to the marginal generation cost of each hour. No revenues from providing reserves or capacity are included. The SRP is calculated from the hourly revenues and costs of each individual unit, where the electricity price is determined by the marginal costs of the most expensive generator required to meet power demand (Eq. (1)).

$$\text{SRP} = \sum_{t=1}^{8760} (\text{Price}_{\text{electricity}}(t) * \text{Production}_{\text{electricity}}(t) - \text{Cost}_{\text{fuel}}(t) - \text{Cost}_{\text{VOM}}(t) - \text{Cost}_{\text{CO}_2}(t)) \quad (1)$$

The discounted payback time of each unit also includes the fixed O&M (FOM) costs and annualized TCR investment costs, but no interest costs during operation (Eq. (2)). A discount rate of 7% is used. The DPT is based on the SRPs calculated for the years 2030 and 2050. We assume that plants are retired after their technical lifetime has been reached.

$$\text{DPT} = \ln \left( \frac{1}{1 - \frac{\text{Investment} + \text{Discount Rate}}{\text{SRP} - \text{Cost}_{\text{FOM}}}} \right) / \ln(1 + \text{Discount Rate}) \quad (2)$$

### 3. Input data

This section provides an overview of power plant parameters, as these novel data are a key input into the models. The other input data for MARKAL are discussed in Appendix C, and REPOWERS input data in Appendix D.

#### 3.1. Power plant flexibility parameters

An overview of flexibility parameters is given in Table 3 and Appendix B. The results show that modern power plants are relatively flexible, even nuclear and PC(-CCS) power plants. IGCC power plants are relatively inflexible because of their inflexible Air Separation Unit (ASU) and gasifier.

Please note that these figures depict the current and future state-of-the-art flexibility parameters. Older plants are (much) less flexible, as flexibility was less important in the past. Moreover, fast ramp rates and fast startups will result in larger thermal stress on equipment and hence reduce its technical lifetime. Power plant operators may therefore opt for more gradual ramping and startups in practice.

#### 3.2. Power plant part-load efficiencies

State-of-the-art part-load efficiencies were collected from technical reports and manufacturer specifications. Per technology, a second-order part-load efficiency curve is plotted based on the

**Table 3**  
Flexibility parameters of power plants per technology, based on Appendix B.

Technology	Minimum load (% of max capacity)	Ramp rate (% of max capacity (min))	Start-up time (h)			Start-up cost (€/MW <sub>installed</sub> per start) <sup>c</sup>		
			Hot start <sup>b</sup>	Warm start <sup>b</sup>	Cold start <sup>b</sup>	Hot start <sup>b</sup>	Warm start <sup>b</sup>	Cold start <sup>b</sup>
<i>Nuclear</i> <sup>d</sup>								
2000	25 ± 5	5 ± 1	3 ± 1	8 ± 2	20 ± 5	39 ± 12	46 ± 14	75 ± 23
2010	25 ± 5	5 ± 1	3 ± 1	8 ± 2	20 ± 5	39 ± 12	46 ± 14	75 ± 23
2020	25 ± 5	5 ± 1	3 ± 1	8 ± 2	20 ± 5	39 ± 12	46 ± 14	75 ± 23
2030	20 ± 5	5 ± 2	3 ± 1	8 ± 2	20 ± 5	39 ± 12	46 ± 14	75 ± 23
<i>PC(-CCS)</i> <sup>e</sup>								
2000	40 ± 10	2.5 ± 1.5	2 ± ½	4 ± 1	8 ± 2	39 ± 12	46 ± 14	75 ± 23
2010	35 ± 10	4 ± 2	2 ± ½	4 ± 1	8 ± 2	39 ± 12	46 ± 14	75 ± 23
2020	25 ± 10	5 ± 2	2 ± ½	4 ± 1	8 ± 2	39 ± 12	46 ± 14	75 ± 23
2030	20 ± 10	6 ± 2	2 ± ½	4 ± 1	8 ± 2	39 ± 12	46 ± 14	75 ± 23
<i>IGCC</i> <sup>f</sup>								
2000	50 ± 10	2.5 ± 2	6 ± 2	n/a	90 ± 10	n/a	n/a	n/a
2010	50 ± 10	3 ± 2	6 ± 2	n/a	90 ± 10	n/a	n/a	n/a
2020	45 ± 10	4 ± 2	5 ± 2	n/a	90 ± 10	n/a	n/a	n/a
2030	40 ± 10	4 ± 2	5 ± 2	n/a	90 ± 10	n/a	n/a	n/a
<i>NGCC(-CCS)</i>								
2000	45 ± 10	5 ± 3	2 ± ½	3 ± ½	4 ± 1	27 ± 11	39 ± 20	57 ± 29
2010	45 ± 10	6 ± 2	1 ± ½	2 ± ½	3 ± 1	27 ± 11	39 ± 20	57 ± 29
2020	40 ± 15	7 ± 2	1 ± ¼	2 ± ½	3 ± 1	27 ± 11	39 ± 20	57 ± 29
2030	25 ± 10	9 ± 2	1 ± ¼	2 ± ½	3 ± 1	27 ± 11	39 ± 20	57 ± 29
<i>GT</i>								
2000	40 ± 15	15 ± 5	¼	¼	½	13 ± 6	16 ± 8	23 ± 12
2010	40 ± 15	15 ± 5	¼	¼	½	13 ± 6	16 ± 8	23 ± 12
2020	35 ± 15	15 ± 5	¼	¼	½	13 ± 6	16 ± 8	23 ± 12
2030	20 ± 10	20 ± 5	¼	¼	½	13 ± 6	16 ± 8	23 ± 12
Sources	[7,14,33–39]	[7,14,33–38,40]	[7,14,33–37]	[7,14,33–37]	[7,14,33–37]	[41]	[41]	[41]

<sup>a</sup> Figures depict the typical state-of-the-art performance per decade.

<sup>b</sup> Starts are classified based on the elapsed time since shutdown. We distinguish hot (offline for <12 h), warm (offline for 12–72 h) and cold (offline for >72 h) starts.

<sup>c</sup> The broad definition of start-up costs is used, without accounting for CO<sub>2</sub> credit costs (Appendix B).

<sup>d</sup> Limited nuclear power plant start-up costs have been found in the literature. Start-up costs equal to those of PC power plants are assumed based on [13].

<sup>e</sup> Co-firing of biomass is assumed to not affect the flexibility parameters of PC-CCS power plants.

<sup>f</sup> No IGCC warm startup time or start-up costs have been found in the literature.

**Table 4**  
Description of plotted part-load efficiency curves per technology based on curves from literature.

Index <sup>a</sup>	Nuclear	PC	PC-CCS	IGCC	NGCC	NGCC-CCS	GT
<i>a</i>	0.522	0.818	0.746	0.432	0.715	0.648	0.406
<i>b</i>	1.135	0.353	0.458	1.225	0.478	0.570	1.155
<i>c</i>	-0.66	-0.17	-0.20	-0.66	-0.19	-0.22	-0.57
<i>r</i> <sup>2</sup>	0.99	0.84	- <sup>b</sup>	0.99	0.88	- <sup>c</sup>	0.97
Sources	[34]	[34,36,37,44,45]	[35,43,46]	[34]	[36,37,42,47–50]	[35,50]	[36,51–53]

<sup>a</sup> Curves are described by the function  $y = a + bx + cx^2$ , where *x* is the load of the power plant as % of max load.


<sup>b</sup> Curve is based on the PC curve without CCS, which is reduced by an efficiency penalty that ranges from 8%-points at full load to 9%-points at 40% load. No *r*<sup>2</sup> is associated with this approach.

<sup>c</sup> Curve is based on the NGCC curve without CCS, which is reduced by an efficiency penalty that ranges from 7%-points at full load to 8%-points at 40% load. No *r*<sup>2</sup> is associated with this approach.

reported data points. These plotted curves express the relative efficiency as a percentage of the full-load efficiency to simplify comparing different technologies (Table 4). The plotted curves show that the gas turbine based technologies have relatively poor part-load performance, resulting from a lower turbine inlet temperature (Fig. 2) [42]. Also, the performance penalty of the CO<sub>2</sub> capture unit becomes progressively larger at lower load levels, resulting from larger throttling losses to keep sufficient steam pressure to the stripper, and less efficient compression of CO<sub>2</sub> [35,43].

### 3.3. Power plant costs and full-load efficiencies

A dataset of techno-economic parameters has been constructed from recent sources. Firstly, the current typical state-of-the-art specifications were determined for all power plants based on these sources. Next, the expected developments



**Fig. 2.** Curves of the relative part-load efficiency as % of full-load efficiency.

in costs and efficiencies until 2050 were compared between the sources, and the most likely development was applied to the present-day specifications.

Efficiencies are mostly based on the efficiency projections of Van den Broek and the International Energy Agency (IEA) [5,16]. Conservative values are chosen, because capacity factors are expected to decrease. This will likely increase demand for somewhat cheaper, less efficient installations. Investment costs are based on projections of IEA and the European Climate Foundation, because they correspond with current prices and reflect recent developments (such as solar PV investment cost reductions, and offshore wind power being relatively expensive) [3,5]. Projected O&M costs are based on IEA costs, which are split between variable and fixed costs based on ratios reported by the Global CCS Institute [5,54].

### 3.4. Power plant outages

Power plant outage patterns are calculated as stochastically, exogenously to the model. Large coal and natural gas fired power plants are modeled as unavailable for 5% of the time on average [60,61]. Once unavailable, the mean time to repair is modeled to be 50 h [62,63].

## 4. Results

### 4.1. Power system results

The most cost-effective power system configurations are calculated with MARKAL (Fig. 3). For the Stalemate, Global Union and Fuel Shift scenarios with lower emission targets, a clear shift can be seen toward renewables and CCS capacity. In the Global Union scenarios, the PC-CCS capacity is co-fired with biomass up to the technical limits, resulting in negative emissions. In the Fuel Shift scenario, 0.1–0.7 GWe of power generation capacity is available at polygeneration plants.

Fig. 4 shows the annual power generation per generator as calculated with REPOWERS. Low-carbon, capital intensive generators like renewables and coal-fired power plants deliver the largest share of generated electricity in all scenarios. The remainder is delivered by natural gas fired generators, resulting from the relatively high natural gas prices. The REPOWERS results resemble the MARKAL results strongly (Fig. 5). One main difference is observed: NGCC power production is reduced by 50–80%, as it is




Fig. 3. Generation capacities calculated with MARKAL model.




Fig. 4. Electricity generation per scenario as calculated with the REPOWERS model.




Fig. 5. Electricity generation per scenario as calculated with the MARKAL model.

replaced by imports of cheaper, base-load power from abroad in the REPOWERS model. Also, PC(-CCS) power production decreases by up to 20% in scenarios with large imports. In scenarios with exports, PC(-CCS) power production increases by up to 20%, which may be the result of its better part-load efficiency and minimum load level compared to NGCC(-CCS) generators. Up to 4% of demand is generated by polygeneration facilities in the Fuel Shift outcome of MARKAL, and replaced by PC-CCS generation in the REPOWERS runs.

Electricity is generally imported from other countries, as shown in Fig. 6. The relatively low-cost generation by renewable, nuclear and coal-fired generators abroad is responsible for this. Only in the Stalemate and Fuel Shift 2050 scenarios, the large share of renewables in the Netherlands decreases the net exchange volume. The total trading volume is not much affected. It is higher in the Global Union scenarios (43 TWh/year) than in the other scenarios (36 TWh/year,  $\pm 3$  TWh).

CO<sub>2</sub> emissions increase strongly in the Baseline 2050 scenario, because the share of coal-fired generation increases by 70%. Despite its early merit order position, significant shares of wind power production are curtailed, especially in the Stalemate and Fuel Shift scenarios (Table 6). This curtailment primarily occurs during high wind, low load situations, when sufficient thermal capacity is needed to supply reserves. High renewable penetration levels in neighboring countries are simulated in the Global Union scenarios, which also affect wind curtailment in the Netherlands.

The reduction in efficiency of the 2030 low-carbon scenarios is comparable to the 2030 and 2050 Baseline efficiency reduction ( $\sim 1\%$ ), while the 2050 low-carbon scenarios have a slightly higher reduction ( $\sim 1.5\%$ ). The efficiency reduction correlates strongly to the average hourly variability in power output of thermal power plants ( $r^2 = 0.81$ ). This variability in low-carbon scenarios varies  $\pm 40\%$  from that of the Baseline scenarios. Four underlying factors correlate with the efficiency reduction: (1) the absolute interconnection flows ( $r^2 = 0.67$ ): power exchange causes variability; (2) centralized thermal power production ( $r^2 = 0.62$ ): the efficiency of large power plants is primarily affected; (3) IRES power production ( $r^2 = 0.46$ ): IRES increase the variability in the system; (4) the variability of the load itself ( $r^2 = 0.38$ ). Especially NGCC(-CCS) and GT units operate flexibly, so they contribute most strongly to the efficiency reduction.

The efficiency reductions increase the specific CO<sub>2</sub> emissions by 0.004–0.006 tCO<sub>2</sub>/MWh in the Baseline scenarios, and 0.0004–0.0007 tCO<sub>2</sub>/MWh in the low-carbon scenarios. Even if these extra emissions would be fully attributed to IRES, the IRES emissions are still 0.05–0.8% of those of a PC power plant per MWh.

The power system costs vary between scenarios (Table 7). The fuel, CO<sub>2</sub> and investment costs are the most important components, while the variable O&M costs are  $\sim 10\%$  of the fuel costs, and fixed O&M costs 20–25% of the annualized investment costs. Startup costs are negligible. The total costs are affected by five factors:




Fig. 6. Net power exchange with neighboring countries per scenario as calculated with REPOWERS model.

Table 5

Techno-economic parameters of current and future centralized power plants. Sources: [3,5,7,16,54–57].

Technology	2010 LHV electrical efficiency (%)	Development of efficiency per decade until 2050 (%-pt) <sup>a</sup>	2010 Investment cost (€ <sub>2011</sub> /kW) <sup>b</sup>	Development of investment costs per decade until 2050 (%) <sup>a</sup>	2010 Fixed O&M cost (€ <sub>2011</sub> /kW/yr)	2010 Variable O&M cost (€ <sub>2011</sub> /MWh)	Range in fixed and variable O&M costs <sup>a</sup>	Development of O&M costs per decade until 2050 (%)
NGCC <sup>c</sup>	60% ( $\pm 10\%$ )	+1.0	700 ( $\pm 30\%$ )	-2	15	1.2	( $\pm 50\%$ )	0
GT	38% ( $\pm 5\%$ )	+1.0	370 ( $\pm 10\%$ )	0	9	0.8	( $\pm 10\%$ )	0
PC <sup>c, d</sup>	47% ( $\pm 15\%$ )	+1.7	1500 ( $\pm 40\%$ )	-4	25	3.0	( $\pm 60\%$ )	0
IGCC <sup>c, e</sup>	47% ( $\pm 15\%$ )	+2.0	1800 ( $\pm 20\%$ )	-4	40	3.0	( $\pm 30\%$ )	-3
NGCC-CCS	52% ( $\pm 10\%$ )	+1.3	1300 ( $\pm 20\%$ )	-7	22	2.1	( $\pm 100\%$ )	-6
PC-CCS	36% ( $\pm 20\%$ )	+3.0	2500 ( $\pm 40\%$ )	-9	36	5.6	( $\pm 100\%$ )	-7
IGCC-CCS <sup>e</sup>	38% ( $\pm 20\%$ )	+2.7	2600 ( $\pm 30\%$ )	-7	57	4.5	( $\pm 30\%$ )	-6
Wind onshore			1230 ( $\pm 30\%$ )	-2	18		( $\pm 70\%$ )	-2
Wind offshore			3300 ( $\pm 40\%$ )	-20	74		( $\pm 60\%$ )	-16
Nuclear			3000 ( $\pm 40\%$ )	0	73		( $\pm 40\%$ )	0
Solar PV			2080 ( $\pm 100\%$ )	-25	21		( $\pm 100\%$ )	-6

The ranges show the range of reported values by these studies. The techno-economic parameters of polygeneration facilities are described in [28].

<sup>a</sup> The development shows the projected cumulative improvement of the techno-economic parameters; e.g. NGCC efficiency is projected to be 63% ( $3 \times 1.0\%$ ) in 2040.

<sup>b</sup> Investment costs are based on the total overnight costs (TOC), whenever available. Whenever only the total capital requirement (TCR) investment cost was supplied, it was converted to the TOC based on interest rate and construction time of power plants reported by the specific source [58].

<sup>c</sup> The MARKAL model can also apply retrofits to these units if the base plant was built between 2010 and 2020.

<sup>d</sup> It is assumed that biomass can be co-fired in PC(-CCS) units up to 30% in 2030 and up to 50% in 2050 (energy basis), without affecting the techno-economic parameters.

<sup>e</sup> The projected IGCC developments apply to a situation in which IGCC plants become a mainstream technology [59].

**Table 6**  
Power system performance data of the Netherlands for all scenarios.

	Baseline 2030	Baseline 2050	Stale-mate 2030	Stale-mate 2050	Global Union 2030	Global Union 2050	Fuel Shift 2030	Fuel Shift 2050
Electricity demand (TWh/yr)	147	180	142	166	142	166	133	141
CO <sub>2</sub> price (€/tCO <sub>2</sub> )	0	0	39	121	66	124	95	195
Annual emissions (MtCO <sub>2</sub> /yr) <sup>a</sup>	48	70	18	6	10	−18	11	9
IRES penetration (% of annual load)	18	14	26	38	25%	19	27	41
Annual wind curtailment (% of potential production) <sup>a</sup>	0.4	0.4	2.8	7.7	1.6	3.4	3.1	14.1
Efficiency reduction (% <sup>a,b</sup> )	1.0	1.0	0.7	1.5	1.4	1.6	0.7	1.4
Average variability of residual load (MW/h) <sup>a,c</sup>	648	754	443	817	570	1041	410	771

<sup>a</sup> Calculated with the REPOWERS model.

<sup>b</sup> The efficiency reduction is the percentage – difference between the average realized efficiency of a thermal power generator and its nominal, full load, efficiency. The weighted average of all generators is calculated based on the annual power production of each individual generator. The reduction is caused by lower part-load efficiencies (Fig. 2).

<sup>c</sup> The residual load is defined as the load minus IRES production and exports, and has to be provided by thermal power plants.

**Table 7**  
Power system cost data of the Netherlands for all scenarios.

	Baseline 2030	Baseline 2050	Stale-mate 2030	Stale-mate 2050	Global Union 2030	Global Union 2050	Fuel Shift 2030	Fuel Shift 2050
Fuel costs (M€/yr)	2876	4019	3138	4273	2520	4732	3294	2986
Coal (M€/yr)	1283	2335	1264	2318	1109	1465	1381	744
Natural gas (M€/yr)	1528	1666	1812	1673	810	373	1864	2239
Biomass (M€/yr)	0	0	0	264	551	2892	0	0
Other (M€/yr)	65	19	63	18	50	2	50	3
Variable O&M costs (M€/yr)	217	331	234	394	283	489	282	249
Start-up costs (M€/yr)	36	40	44	59	52	61	40	54
CO <sub>2</sub> costs (M€/yr)	0	0	697	931	673	−2536	1068	1693
<b>Total short-run system costs (M€/yr)</b>	<b>3129</b>	<b>4390</b>	<b>4113</b>	<b>5657</b>	<b>3528</b>	<b>2746</b>	<b>4684</b>	<b>4982</b>
Investment costs (M€/yr)	3941	4185	4669	5528	4523	5008	5444	5899
Fixed O&M costs (M€/yr)	962	1042	1116	1358	882	1067	1165	1339
<b>Total system costs (M€/yr)<sup>a</sup></b>	<b>8033</b>	<b>9618</b>	<b>9899</b>	<b>12,543</b>	<b>8933</b>	<b>8821</b>	<b>11,292</b>	<b>12,220</b>
Average electricity price (€/MWh) <sup>b</sup>	61	68	72	85	56	31	71	51
Average total generation costs (€/MWh) <sup>c</sup>	68	64	80	74	77	64	88	78

<sup>a</sup> Total annual system costs also include annualized share of the investment cost (based on a discount rate of 7%) and the fixed O&M costs.

<sup>b</sup> Average electricity price calculated with the REPOWERS model according to the current market design (payment per MWh generated, on par with the production cost of the marginal generator of each hour).

<sup>c</sup> Average total generation costs calculated by dividing the “total system costs” by the amount of electricity generated in the Netherlands.

- (1) Larger share of intermittent renewables: lower fuel cost and higher investment cost, as shown in the Stalemate 2050 and Fuel Shift 2050 scenarios.
- (2) Biomass co-firing: higher fuel and lower CO<sub>2</sub> costs. The Global Union 2050 scenario realizes 18 MtCO<sub>2</sub> negative emissions with co-firing of biomass in PC-CCS plants, which are worth 2.2 billion Euros.
- (3) Higher CO<sub>2</sub> price: higher CO<sub>2</sub> costs. These costs comprise up to 14% of total system costs in the Fuel Shift 2050 scenario.
- (4) More electricity imports: lower short-run costs. Imports mainly reduce CHP and NGCC(-CCS) electricity generation in the Netherlands as compared to the MARKAL simulations.
- (5) More generation capacity: higher investment costs. Sufficient capacity is available in the scenarios to meet peak demand and reserves. NGCC and GT capacity is relatively expensive compared to the power it generates: 2–5 times, and 1.5–3 times the average total costs per MWh, respectively.

Comparing the power system costs to the electricity price shows that the price does not cover the costs of the system in most scenarios: only 84% (±30%) is covered (Table 7). This suggests that the current energy-based power sector market design does not seem suitable for future low-carbon scenarios. Moreover, Table 7

shows that power generation in low-carbon power systems is on average 17% (±15%) more expensive per MWh than in the Baseline. On average, 25% of this increase in cost is caused by the CO<sub>2</sub> price. The opposite is true for the Global Union scenarios, which have lower electricity prices than the Baseline thanks to negative emissions and cheap imports.

#### 4.2. Flexibility of the system

System flexibility is assessed by determining if sufficient reserves are available, and by zooming in on the flexibility of individual generators and the generation pattern of a typical week. We only look at the year 2050, as this year has the highest penetration of intermittent renewables.

As shown in Fig. 7, all scenarios can supply sufficient reserves at all times. Only the Fuel Shift scenario has difficulties supplying sufficient spinning reserves, because relatively few units have to supply large amounts of spinning reserves during periods of high wind power production. Moreover, a lack of (mainly natural-gas fired) capacity reduces the available hourly standing reserves in this scenario. Sufficient down reserves can be supplied at all times, either by thermal power generators or curtailed renewable generators.

To zoom in on the flexibility and profitability of power plants, a selection of three typical new power plants was made per scenario:




Fig. 7. Modeled reserve sizes with >99% availability (depicted by the bars), and the availability of sufficient reserve for 8760 h per year (depicted by the diamonds).

PC(-CCS), NGCC(-CCS) and GT power plants, which traditionally represent base-load, mid-load and peak-load generation, respectively. These new power plants have better efficiencies and flexibility specifications than older plants, and are most frequently committed within their class.

The flexibility performance of the generators does not differ much between the scenarios, as shown in Table 8. The PC-power plants (which are equipped with CCS and co-fired with biomass in some scenarios) show high capacity factors and little variability in output. As a result, the reduction in efficiency is also very limited (0.1–0.3%-point). In contrast, NGCC plants (equipped with CCS in the Global Union and Fuel Shift scenarios) have very low capacity factors in all scenarios but the Fuel Shift scenario: they have in fact become balancing plants, with high variability in output and many start-ups. Their efficiency is reduced by 0.3–1.7%-point compared to their nominal efficiency. The role of gas turbine generators has shifted from peak-load generator to supplier of spinning and sub-hourly reserve capacity. These generators often run near the minimum level, which causes a substantial reduction in efficiency of 4.6–8.5%-points.

At a unit level, all low-carbon scenarios show higher start-up costs and higher variability of PC(-CCS) and NGCC(-CCS) units than the Baseline scenario, which is expected because of the larger share of renewable generators. The exception is the relatively low variability of the Fuel Shift scenarios, where base-load generators with

CCS are an attractive generator type, also for exporting power. The efficiency reduction is not considerably affected: the adverse effects of large shares of renewables on individual units appear limited.

The 2050 generation patterns of weeks 21 (high IRES production and high variable residual load) and week 47 (hours of very low IRES production) are shown in Fig. 8. All scenarios but the Fuel Shift scenario rely heavily on PC(-CCS) power plants. These turn out to be flexible enough to adapt to fast variations: In the Global Union scenario, the system is able to run reliably with these generators and 1.5 GW of gas turbine capacity (5% of total thermal power plant capacity). Both generator types tend to avoid startup costs and to ramp back rather than be switched off, so that they can supply spinning reserves. In all scenarios but the Baseline scenario, the solid-fuel fired power plants are equipped with CCS to lower their emissions. Natural gas fired capacity has a late position in the merit order, and is utilized for both reserve provision and limited power production. NGCC(-CCS) generators are frequently switched off in all low-carbon scenarios when residual demand is small. Only the Fuel Shift scenario has a large share of NGCC-CCS generation, which is still ramped back during hours of little residual load. Wind power production makes up a large share of power production, and together with Solar PV largely determines the required size of reserves. Exchange with neighboring countries plays an important role, as the trade volumes are sizable.

Table 8  
Flexibility performance of individual generators for all scenarios, calculated with REPOWERS.

Scenario	Power plant type	Traditional role	Capacity (MW)	Annual capacity factor (%)	Starts (#/yr)	Average variability <sup>a</sup> (% of capacity)	Average CO <sub>2</sub> emissions (tCO <sub>2</sub> /MWh)	Average spinning reserve provision (% of capacity)	Efficiency reduction <sup>b</sup> (%-points)	Start-fuel consumption of unit <sup>c</sup> (% of fuel use)	Start-fuel consumption of unit <sup>c</sup> (TJ/yr)
Baseline 2050	PC 2040	Base	700	89	4	1	0.66	7.2	0.2	0.1	31
	NGCC 2040	Mid	600	15	54	5	0.33	1.4	1.1	2.7	130
	GT	Peak	100	11	77	8	0.60	3.7	5.7	0.8	8
Stalemate 2050	PC-CCS 2040	Base	700	89	9	0	-0.08	4.9	0.3	0.2	69
	NGCC 2040	Mid	600	41	158	11	0.33	4.2	1.7	2.9	379
	GT	Peak	100	22	8	4	0.62	9.5	6.9	0.0	1
Global Union 2050	PC-CCS 2040	Base	700	89	53	2	-0.24	4.9	0.3	1.0	408
	NGCC-CCS 2040	Mid	600	21	146	6	0.04	1.6	1.3	4.6	350
	GT	Peak	100	20	11	1	0.65	9.6	8.4	0.1	1
Fuel Shift 2050	PC-CCS 2040	Base	700	87	13	1	0.08	5.0	0.2	0.2	100
	NGCC-CCS 2040	Mid	600	74	112	3	0.04	3.7	0.4	1.1	269
	GT	Peak	100	20	6	1	0.65	9.6	8.6	0.0	1

<sup>a</sup> The average variability is calculated for all 8760 h per year.

<sup>b</sup> The reduction in efficiency compared to the nominal efficiency, as caused by lower part-load efficiencies. The realized efficiency is calculated from the annual fuel consumption and annual power production.

<sup>c</sup> The fuel consumption is based on consumption approximations by the authors, as shown in Table B.2.




Fig. 8. Power production in week 21 for the 2050 scenarios.

Renewable electricity production and power exchange dampen the day-night variations in residual load in this week, but they can also exacerbate variations depending on (foreign) renewable electricity generation.

#### 4.3. Profitability of power plants

A post analysis is performed to determine the profitability of power plants based on the current energy-based market design. The performance per unit type is shown in Table 9, and a detailed profitability overview is shown in Table 10 for the same generators as in Table 8. Again, these generators are the most recent and profitable within their class.

Nuclear and new solid-fuel fired power plants form the backbone of the power system in all scenarios, in terms of power production (capacity factors >80%) and spinning reserve provision ( $50 \pm 20\%$  of all spinning reserves). This does not guarantee economic operation: electricity prices have to be sufficiently high (>75 €/MWh for PC-CCS) to recoup the initial investment within 25 years. Older solid-fuel fired power plants have a similar role, but with lower capacity factors, and longer payback times.

The situation for new NGCC(-CCS) plants is generally uneconomic because their capacity factors are low, and because their profits are too small. NGCC(-CCS) generators are often the price

setters: between 60% and 80% of the hours in all '50 scenarios, except for 20% in the Fuel Shift scenario. Thus, their short-run profits are therefore only slightly positive, which is not enough to cover the fixed O&M costs. NGCC(-CCS) plants supply hourly reserves, the revenues of which could improve the business case, but the model does not remunerate for these. Older NGCC capacity has very low capacity factors in all scenarios, and should probably be decommissioned.

Despite their small capacity in most scenarios, gas turbines play an important role in all scenarios by supplying spinning reserves (10–30% in '50 scenarios). More importantly, they supply sub-hourly reserves ( $55 \pm 15\%$  of these reserves in the '50 scenarios). They are the most important source of sub-hourly reserves, together with CHP generators (if these are available in the scenario). Because gas turbines are the price setters whenever they run, they do not post profits, and run at a loss.

Solar PV power generation is uneconomic in all scenarios: the construction of these installations is fully driven by governmental RES-targets. Wind power generation is economic in most scenarios: only in the Global Union scenarios the electricity prices are not sufficient to cover its investment costs.

Overall, the post-analysis shows that the payback time of base load generators is economic (<25 years) in the Baseline, Fuel Shift and Stalemate 2050 scenarios and uneconomic (>25 years) in the other scenarios.

**Table 9**  
Performance of power plants types per scenario.

Unit type	Role of generator per scenario	Discounted payback time (yr)
NUC	All '30: base-load (CF: ~95%)	GU'30: >50 All others: 20–30
PC(-CCS) (old) <sup>a</sup>	BL, GU'50, FS'50: mid-merit (CF: 50–75%) SM, GU'30, FS'30: base-load (CF: 75–90%)	BL, SM'50: 10–20 All others: >50
PC(-CCS) (new) <sup>a</sup>	All: base-load (CF: 80–95%)	BL, SM'50: 7–10 FS'30: 34–40 All others: >50
NGCC(-CCS) (old) <sup>a</sup>	All: Peak generator (CF: 0–10%)	All: >50
NGCC(-CCS) (new) <sup>a</sup>	BL, GU: peak load (CF: 10–25%) SM: mid-merit (CF: 15–40%) FS: base-load (CF: 65–80%) <sup>b</sup>	FS'30: 42 → 50 All others: >50
GT	All: peak/mid-merit (CF: 20–30%)	All: >50
CHP <sup>c</sup>	BL, SM, GU'30, peak/mid-merit (CF: 10–50%) FS, GU'50: Peak-load (CF: 0–20%)	Very diverse <sup>c</sup>

Abbreviations: BL – Baseline, SM – Stalemate, GU – Global Union, FS – Fuel Shift, CF – capacity factor, SR – spinning reserves.

<sup>a</sup> Old units have been built  $\geq 20$  years ago; more recent units are labeled “new.” Units remain in the generator mix until their technical lifetime has run out: 40 years for PC plants, and 30 years for NGCC plants.

<sup>b</sup> In the FS2050 scenario, 3.9 GW new NGCC-CCS capacity runs base-load (CF: 70–80%), and 8.5 GW runs mid-merit (CF: 30–65%).

<sup>c</sup> Depends on the CHP type, the heat demand and the fuel costs.

#### 4.4. Sensitivity analysis

A sensitivity analysis was performed with the REPOWERS model for seven parameters, shown in Table 11. We assessed the effect on the electricity price, generator shares, average efficiency reduction and international exchange of electricity. The fuel prices strongly affect the electricity price, and lower fuel prices cause a swap from PC to NGCC generators (Fig. 9). This generally increases the average reduction in power plant efficiency, as NGCC part-load operation is less efficient. Variations in the biomass price do not affect the performance parameters, as the merit order position of co-firing PC-plants does not change.

An increased CO<sub>2</sub> price reduces PC generation and increases NGCC generation. Moreover, electricity prices increase. The

**Table 10**  
Profitability of selected generators.

Scenario	Traditional role	PP type	Fuel cost (M€/yr)	Variable O&M cost (M€/yr)	Start-up cost (M€/yr)	CO <sub>2</sub> cost (M€/yr)	Short-run profit <sup>a</sup> (M€/yr)	Discounted payback time <sup>b</sup> (yr)
Baseline 2050	Base	PC 2040	145	16.4	0.2	0	<b>193</b>	<b>7</b>
	Mid	NGCC 2040	46	0.7	1.4	0	<b>21</b>	<b>&gt;50</b>
	Peak	GT	10	0.1	0.1	0	<b>–2</b>	<b>&gt;50</b>
	RES	Wind	–	–	–	–	<b>1369</b>	<b>12</b>
Stalemate 2050	Base	PC-CCS 2040	194	25.8	0.4	–54	<b>282</b>	<b>7</b>
	Mid	NGCC 2040	110	1.8	3.8	87	<b>8</b>	<b>&gt;50</b>
	Peak	GT	19	0.2	0.0	15	<b>–12</b>	<b>&gt;50</b>
	RES	Wind	–	–	–	–	<b>4491</b>	<b>10</b>
Global Union 2050	Base	PC-CCS 2040	217	23.4	2.4	–148	<b>54</b>	<b>&gt;50</b>
	Mid	NGCC-CCS 2030	25	1.2	3.7	3	<b>10</b>	<b>&gt;50</b>
	Peak	GT	10	0.2	0.0	14	<b>–15</b>	<b>&gt;50</b>
	RES	Wind	–	–	–	–	<b>611</b>	<b>&gt;50</b>
Fuel Shift 2050	Base	PC-CCS 2040	106	27	0.6	84	<b>34</b>	<b>&gt;50</b>
	Mid	NGCC-CCS 2040	145	4	2.7	27	<b>3</b>	<b>&gt;50</b>
	Peak	GT	10	0	0.0	22	<b>–19</b>	<b>&gt;50</b>
	RES	Wind	–	–	–	–	<b>2913</b>	<b>25</b>

<sup>a</sup> The short term profit is calculated by deducting the fuel, variable O&M, start-up and CO<sub>2</sub> costs from the annual revenue in the current market design. No electricity price mark-up or revenues from supplying reserves are included.

<sup>b</sup> The discounted payback time is equal to the year when the cumulative sum of discounted short-term profits and fixed O&M costs equals the initial investment costs. A discount rate of 7% is used.

**Table 11**  
Sensitivity analysis parameters.

Parameter	Range varied (%)	Range based on
All fuel prices	±50	Range in Table 2
Biomass price	±50	Same as for fuel prices
CO <sub>2</sub> price	±50	Uncertainty [19]
Minimum load level of power plants	±50	Range in Table 3
Ramp rate of power plants	±50	Range in Table 3
Reserve size of system	±50	Reported range [8]
No international exchange	n/a	Assumption
No remuneration for negative emissions (no –CO <sub>2</sub> )	n/a	Assumption

opposite effect applies for the Global Cooperation scenario, as its PC emissions are lower than NGCC emissions due to biomass co-firing.

An increase in minimum load levels results in a slight shift from PC to NGCC capacity (Fig. 9). As a result, the electricity prices increase somewhat. The efficiency penalty decreases, as the minimum load limits the most inefficient operation at very low loads.


The ramp rate of power plants only slightly affects the indicators (0–2% variation). Also, an increased reserve size has a minor impact: 1% increase in electricity price, up to 3% more NGCC generation. The reverse trend applies for a smaller reserve size.

The effect of no exchange on the electricity price is a small decrease in efficiency reduction (Fig. 9). It results in both more PC and NGCC generation in the Global Union and Fuel Shift scenarios. No remuneration for negative emissions only affects the Global Union scenario. Especially the effect on the electricity price is steep. The reduction in efficiency becomes smaller as PC-CCS plants are not the cheapest option by default anymore, so NGCC generation displaces their most inefficient operation.

## 5. Discussion

### 5.1. Soft-link approach

To the knowledge of the authors, only Deane et al. also soft-linked power system optimization and UCED models [31]. In



**Fig. 9.** Selected sensitivity analysis outcomes. (a) In the Global Union scenario, the labels are reserved (higher electricity price at lower CO<sub>2</sub> price). (b) In the Global Union scenario, the labels are reserved (efficiency reduction at lower CO<sub>2</sub> price). (c) In the Stalemate and Fuel Shift scenarios, the labels are reversed (the smallest efficiency reductions are seen with increased minimum load levels).

fact, their observations are in line with those of this study. The calculated generation by the UCED model and optimization model are largely the same. Moreover, our UCED model also reports higher wind-curtailment, and higher capacity factors for gas turbines than the optimization model.

A mismatch exists between the models: the uneconomic payback times calculated with the REPOWERS model do not warrant the large investments in new capacity projected by MARKAL. Thus, there is a ‘missing money’ problem: not enough money is made to warrant new investments under the current market design. The simulated electricity prices per MWh cover only 84% ( $\pm 30\%$ ) of the total power system costs per MWh. Part of the missing 16% could be from reserve markets, for which the REPOWERS model does not account, and the remaining money would have to be made by other means, e.g. alternative market designs (e.g. a capacity market) or policy support. It should be noted that future fuel prices and investment costs strongly affect the payback times, so future analysis should address this.

## 5.2. Flexibility

The literature review indicates that the operating flexibility can be improved, to the extent that coal/biomass-fired power plants are often flexible enough to accommodate for large changes in residual demand. However, when extra flexibility is implemented, operators could refrain from utilizing the improved start-up times and ramp rates, because they incur extra costs [41].

Moreover, it is currently unknown how variable CO<sub>2</sub> flows from capture units can be handled by the transport and injection infrastructure at a national scale. Studies report that the variability can be handled when a single source and sink are connected by a pipeline, as long as the CO<sub>2</sub> flow is heated during startup [64], and the CO<sub>2</sub> flow does not become smaller than 20% of the rated volume [65].

## 5.3. Potential improvements to the models

Better demand patterns would improve the results. The electricity and heat demand profiles in this study are based on present-day profiles, which are extrapolated based on total projected electricity and heat demand. Yet, the profiles may significantly change in the future as a result of further electrification and energy efficiency measures.

CHP generators also supply a significant amount of electricity ( $\sim 20\%$  in the Baseline and Stalemate scenarios), because cost allocations to heat production lower their cost of electricity. Both models now use crude heat patterns for two aggregated sectors, for 3 season types. More detailed heat patterns could increase the variability of power production by CHP units, and therefore increase the need for flexibility in the system.

Only thermal and renewable generators can generate electricity and supply reserve capacity in our models. Other technologies could potentially also supply these (such as electricity storage [66], demand side management [36] and pumped hydro storage abroad [67]), which could reduce the overall investment and operational costs of the system.

The simulation of system reserves could be further improved in three ways. Firstly, the reserve sizes could be calculated specifically for the Netherlands, rather than basing them on approximations from other studies. Secondly, the provision of spinning reserves is currently capped at 10% of maximum capacity per unit, because deliveries of frequency reserves are capped. By separately modeling frequency and regulating reserves, the latter spinning reserves can be modeled without a cap. Thirdly, novel generation solutions could supply reserves, such as

electricity storage, demand side management and wind power, which may be particularly beneficial in ‘low load, high wind’ situations.

## 5.4. Representativeness of study results

This study focuses on The Netherlands, but the general trends seen in the results may apply to other European countries too. After all, the power sectors in European countries are operated in the same way, and the European Commission is planning to further harmonize them [68]. Moreover, most power plants that are currently online will have been replaced by the year 2050 based on fuel and investment costs which are relatively uniform throughout the continent.

Still, four factors may change investment decisions and power system operation compared to the Netherlands. Firstly, the geographical location of countries affects the potential of renewable sources such as wind, solar PV and hydropower, which can displace fossil fuel-fired capacity. High penetration of IRES may result in more peak-load capacity investments, and hydropower favors base-load capacity. Secondly, the proximity of neighboring countries determines the extent to which interconnectors can be built. Thirdly, the availability of CO<sub>2</sub> storage locations determines the attractiveness of CCS. A fourth factor are the demand patterns of electricity and heat, which differ based on the climate and the structure of the economy.

In the end, the composition of the power system is largely politically driven, however, rather than price driven [69]. The optimizations performed in this study assume perfect, energy-only markets, which do not exist in practice. If individual countries pursue policies which diverge from these markets, the resulting energy mixes and power system operation will be different.

## 5.5. Coal/biomass-fired power plants

Our results show that biomass co-firing with CCS is promising in scenarios with high CO<sub>2</sub> prices. The business case of this option may have benefited from three assumptions.

- (1) Negative emissions generate CO<sub>2</sub> credits that can be sold at the (high) CO<sub>2</sub> price in the future. This is vital for the combined implementation of biomass and CCS [70,71]. Additionally, no feedback effects of ‘negative emissions’ on the CO<sub>2</sub> price are accounted for. In the Global Union 2050 scenario, these may occur due to the large amount of stored biogenic CO<sub>2</sub>.
- (2) The performance of the pulverized coal fired power plants is not affected by biomass co-firing. However, co-firing of large shares (>30%) of biomass pellets may increase the investment costs by about 5–10%, and reduce the net efficiency by about 1%-point [70,72].
- (3) Biomass co-firing requires large amounts of biomass: 350 PJ/yr in the Global Union 2050 scenario for the Netherlands. Studies indicate that the worldwide technical potential for biomass is large enough to supply these quantities [73,74].

On the contrary, two assumptions may have limited biomass utilization.

- (1) Only biomass co-firing in PC-power plants and biomass gasification in IGCCS are considered in this study. Inclusion of other biomass-fired power generation types (e.g. dedicated combustion and bio-CHP) could further increase biomass utilization.

- (2) The high future biomass prices of 8–9 €/GJ that are used are at the upper range of projected future costs for (torrified) pellets (3–9 €/GJ), because biomass markets are still immature [23–25].

### 5.6. Comparison to other studies

The studies mentioned in the introduction do not report much on flexibility. This may be an indication that flexibility is not a major issue, which is in line with our findings. Whatever these studies mention on flexibility is largely comparable to our results. Similar to the Roadmap 2050 study by ECF, we conclude that the power plants are flexible enough, and that nuclear and coal-fired power plants maintain high capacity factors [3]. Both Bertsch et al. and this study report that the capacity factors of base-load and mid-load plants decrease over time when IRES penetration increases. Bertsch reports a larger average decrease in capacity factor of coal plants between 2030 and 2050: 36%, compared to 8% in this study across all scenarios. [11]. Moreover, Bertsch concludes that the profitability of base-load plants is adequate, of mid-merit is break-even, and of peak-load is not sufficient. We report lower revenues for mid-merit and peak-load capacity, potentially because we do not account for reserve revenues, and because we have more base-load capacity, shifting the merit order position of mid-merit power plants.

## 6. Conclusion

In this study we present a consistent dataset of power plant flexibility parameters. This dataset is used to determine the technical and economic operation of power plants for four distinctly different scenarios, which are simulated with the soft linked MARKAL-NL-UU and REPOWERS models.

Our flexibility dataset shows that power plant may become significantly more flexible in the coming decades: even nuclear power plants and power plants with CCS. The flexibility and part-load efficiencies differ per technology.

Our simulations show that power system operation shows small differences between the scenarios.

Low-carbon scenarios show 2–38% higher variability in residual load in the year 2050 compared to the Baseline. This requires 45–60% more start-ups, especially for NGCC-plants (+150% starts, +50% variability in operation). Moreover, we find that the variability of residual load is the main driver for the efficiency reduction of thermal power plants of 0.6–1.6%.

Still, enough flexibility is present in future power systems to accommodate renewables, due to advances in power plants flexibility. Post-combustion capture units are reported to not reduce the flexibility of their base power plants, and power plants with CCS generate large shares of power (23–62%) in the low-carbon scenarios.

As a result, future low-carbon power systems can be run reliably and with low emissions, when 130% of peak capacity is present (as enforced by MARKAL), and if renewable generation can be curtailed (sometimes strongly: 1.6–14% of annual wind production in low-carbon scenarios).

Lastly, we calculate the economic feasibility based on the current market design that remunerates per MWh generated. All scenarios experience a “missing money” problem with this market design: the price received per MWh (61 €/MWh ± €28) is on average only 84% (±30%) of the total generation costs per MWh (74 €/MWh ± €12). Specifically, mid-merit and peak-load generators do not earn back their investment costs in any of the scenarios, and base-load generators (with CCS) in only half the scenarios.

New or additional market designs could provide the “missing money,” which include capacity, flexibility and reserve markets. Moreover, novel power generation solution (such as demand response and electricity storage) could potentially be more cost-effective than thermal generation capacity.

Recommendations for future research:

- Quantification of profitability of power plants in future power systems for different market designs.
- Evaluation of cost-effective deployment of novel power generation solutions in future power systems, such as demand response and electricity storage.

## Acknowledgements

This research was carried out in the context of the CATO-2-program. CATO-2 is the Dutch national research program on CO<sub>2</sub> Capture and Storage. The program is financially supported by the Dutch government (Ministry of Economic Affairs) and the CATO-2 consortium parties. The authors would like to thank the power plant experts for their input, Joost van Stralen and Özge Özdemir for their technical support and Jos Sijm for his comments.

## Appendix A. Description of MARKAL-NL-UU and REPOWERS models

### A.1. MARKAL-NL-UU model

The MARKAL (MARKet ALlocation) model is a bottom-up linear optimization tool. It optimizes the use of energy sources, energy carriers, and transformation technologies to fulfill energy demand of selected sectors at the lowest cost. The model selects energy transformation technologies from a portfolio of options and is subject to user-defined constraints, such as the maximum allowed CO<sub>2</sub> emissions [26,27].

The MARKAL-NL-UU model is a version of the MARKAL model that optimizes the energy system of the Netherlands [16]. In this study, it is used to calculate the optimal (least-cost) electricity mix until 2050, with a time step of 5 years. For these years, 9 time slices are calculated per year and two types of heat demand are distinguished: must-run demand and flexible demand [16]. The model will build technologies that can generate heat, which may be CHP units or auxiliary boilers.

Input data consist of fuel prices (Table 2), the techno-economic parameters of the current Dutch centralized power plant portfolio (based on the same dataset as used in [17]), as well those of future power plant technologies (Tables 5 and C.1).

Output data include the generator mix, the amount of electricity generated per generation technology and the national CO<sub>2</sub> price. This price is determined by the shadow price of the CO<sub>2</sub> emission constraint, and used as a proxy of the EU ETS carbon price.

#### A.1.1. Assumptions

- The model only considers power production in the Netherlands; interconnections are not included.
- Co-firing of biomass can be done up to 30% in 2030 and 50% in 2050 [70].
- To maintain system reliability, the model will always require 130% of the annual peak load as installed capacity.
- 15% of offshore wind, 10% of onshore wind and 5% of solar PV capacity is treated as firm capacity that contributes to the reliability of the system.

- Heat demand is simulated, but not included in the results. Heat demand is fulfilled by either CHP units or auxiliary boilers.

## A.2. REPOWERS model

REPOWERS is a unit commitment and economic dispatch model based on Lagrangian Relaxation. Its objective is to minimize the short-term costs of power generation whilst meeting power demand and accounting for the technical constraints.

The REPOWERS model is largely based on the description of Virmani et al. [75], only the implementation of the spinning reserves is based on Wood [76]. The model uses Lagrangian relaxation, a computational approach in which the constraints are relaxed by formulating them as sub-problems and introducing a Lagrangian multiplier. By iteratively solving the objective function and the sub-problems, optimal dispatch can be calculated efficiently [77].

REPOWERS calculates the optimal hourly dispatch per week, for 365 days per year. For every hour, power generation has to equal the sum of domestic demand and imports/exports (where imports are considered negative load). Centralized units are modeled individually, and decentralized units, (many of which CHP units), are modeled in an aggregated way with 12 separate unit categories. Each of these categories is treated as a separate unit. The model includes quadratic part-load efficiency curves for all thermal units, and accounts for the following flexibility constraints:

- (1) Each plant has a minimum up and down time (in hours).
- (2) Maximum ramp up and ramp down rates (defined in MW/hour).
- (3) Minimum load level (in MW).
- (4) Start-up and shut-down costs (in €/event).

For REPOWERS, a fixed maximum amount of heat can be generated by CHP units per hour depending on the season. When heat is generated, part of the fuel and emission costs are allocated to heat production by correcting the electric efficiency of the CHP plant with the formula  $\eta_{\text{corrected}} = \eta_e / (1 - (\eta_{\text{th}} / \eta_{\text{boiler}}))$ . A boiler efficiency of 95% is assumed for low quality heat from a heat engine, and a boiler efficiency of 90% is assumed for high quality heat from the other types of installations [78]. It is assumed that CHP units are equipped with auxiliary boilers, so none of the generators are truly must-run.

Power generation from wind and solar PV power generators is based on exogenous production profiles. The model can curtail wind power production in order to maintain the balance between generation and load, and to ensure sufficient spinning reserves are available.

Imports/exports are included by calculating the residual supply curve of the foreign countries directly interconnected to the Netherlands, i.e. Belgium, Denmark, Germany and the U.K. The residual load has to be at least 1 MW; negative residual load is assumed to be curtailed. Foreign generator mixes are based on PRIMES projections and national policy goals. A cost-supply curve is constructed for each of these countries, where marginal costs of each unit category are calculated based on the techno-economic specifications that are also used in the MARKAL model. The supply curve is assumed to be continuous rather than stepwise. The residual supply curves include exchange with the Netherlands, and are iteratively calculated. International exchange of power is assumed to take place in trading-blocks of 4 h, for which a surcharge of €5/MWh is incurred.

Spinning reserves are modeled as capacity that can be made available to the system within 15 min. Spinning reserve requirements can be split between online units and offline units. In REPOWERS only supply by online units is considered. When the

spinning reserve requirement is violated, the output of the most expensive unit in operation is reduced until it reaches its maximum possible contribution (being the smaller of either 10% of the nominal capacity or the maximum ramp up/down capacity in 15 min). Next, the output of the one-but most expensive unit is reduced, and so forth until the requirement is met. More expensive units cover the supply deficit that is created because of this procedure, increasing the total system cost and the electricity price.

The model has been successfully validated against ECN's POWERS model for the year 2006, and against a dynamic programming model for a fictional power system for the same year. Also, it has been used for the ITM project [79].

### A.2.1. Input data

The same efficiencies and variable O&M costs are used as in the MARKAL model. Moreover, a set of standardized flexibility-parameters was composed for the model per generation technology and decade of construction (Table 3). Power plant outage patterns are determined exogenously based on historical outage statistics.

The load and RES-E production patterns are corrected for projected future developments for both the Netherlands and neighboring countries. An exogenous curtailment step is performed for the Netherlands, to ensure a minimum residual load of 4 GW to facilitate model solving.

### A.2.2. Assumptions

- The model only simulates the provision of reserve capacity, not the actual dispatch of reserve capacity.
- The uncertainty in production patterns of intermittent renewable sources is assumed to be covered by increased reserves sizes compared to situations without renewable energy sources.
- Renewable sources have an early position in the merit order, but no priority over thermal power generators.

## Appendix B. Description of flexibility parameters

In this section we provide a definition of each of the flexibility parameters of power plants, followed by a short description of the key factors that determine the flexibility, and potential measures to improve the flexibility. We conclude with a description of start-up costs.

### B.1. Minimum load

The minimum load level is the lowest level at which a power plant can operate for an extended time whilst meeting emission limits, expressed as a percentage of the maximum capacity. The lowest minimum load levels are projected for nuclear and PC power plants. An overview is provided in Table 3.

The 3rd generation nuclear power plants have been designed for load levels as low as 25% of maximum load [80].

PC power plants have seen improvements to the main bottlenecks, which include the firing system, steam turbine and especially the boiler. Current and future improvements include indirect firing, rifled boiler tubing and low-load circulation systems [33,81–83].

The minimum load level of an IGCC is mainly limited by the gasifier and Air Separation Unit (ASU), which can be turned down to about 50% and 70% of maximum load respectively [35]. At lower loads gasifiers experience problems with sustaining the protective slag layer, and the ASU contains a compressor that cannot run at lower loads [47]. Installing multiple gasifiers/ASU trains will reduce the minimum load level of the plant, albeit at extra investment costs. If the plant is designed as a polygeneration plant with

multiple outputs (i.e. electricity, H<sub>2</sub>, FT-liquids, and/or methanol), switching outputs will improve the flexibility in electricity generation [47]. The combined cycle is not expected to be a bottleneck for the minimum load level [35]. As IGCC power plants are not main-stream, there is more uncertainty associated with future developments.

The minimum load levels of NGCC and GT plants are not set by the technical minimum load but by emission limits, as CO and NO<sub>x</sub> emission levels increase considerably at low loads [35]. Currently, the 100 mgNO<sub>x</sub>/N m<sup>3</sup> emission limit is met at NGCC load levels of >45%, and it is expected that through incremental improvements it can be reduced to 40% by 2020 [84]. In time, the use of a parking-load level may become mainstream and reduce the minimum load even further, as shown by the 20% minimum load level of the Alstom KA26 NGCC plant [39], and it is expected that these improvements will become widely adopted in the future. The minimum load level of an GT is slightly lower than that of an NGCC based on the same turbine type [39,85], but the wider variety of GT types results in a larger uncertainty.

The addition of a CO<sub>2</sub> capture unit does not appear to affect the minimum load level, as long as parallel compressor trains are present. Two detailed studies considered a PC plant with CCS in detail: a FEED study by E.ON reports a minimum capture plant operating level of 25%, and a study by Foster Wheeler identified the absorber as the bottleneck with an operating level of 30% of full load [35,64]. More global studies also report that the capture unit does not have an impact [34,86].

### B.2. Ramp rate

The ramp rate is the average speed at which power output can be increased or decreased between the minimum and maximum load levels, expressed as a % of the maximum capacity per minute. Ramping causes the temperature of power plant components to change, resulting in thermal stress that reduces the lifetime of the power plant. As a result, ramping rates are typically lower in practice than the maximum achievable ramp rates, because the maximum rates put a larger strain on the equipment. The selected values shown in Table 3 are therefore conservative estimates based on literature.

Nuclear power plants are projected to be of the 3rd generation until at least 2040 [7], which have ramp rates of 5%/min [80].

The ramping speed of PC plants is mainly determined by the boiler, and to a smaller extent by the steam turbine [87]. Thinner components reduce the thermal stress on these components, which can be achieved with once-through boilers (which have thinner walls than drum type boilers), the use of better materials and an increase in the number of lines in the boiler. Also, better monitoring of the steam turbine can provide operators with better information about its ramping capabilities [33,83,88].

Ramp speeds of an IGCC plant are primarily limited by the gasifier, but the ASU is also relatively inflexible. The IGCC power island has flexible characteristics comparable to a NGCC plant.

The ramp rate of NGCCs is mainly limited by the steam cycle, as gas turbines can ramp quickly [40]. Similar improvements as for PC power plants can increase the ramp speed of the steam cycle. Moreover, the use of attemperators can partly decouple the gas and steam cycles, allowing the gas turbine to ramp more quickly [35]. Auxiliary firing of natural gas in the heat recovery steam generator can boost power production, but comes at an efficiency penalty [40].

GT power plants have the highest ramp rates because of the lack of thick-walled components and inertia in the system. The most flexible GT plants feature blade cooling by air instead of steam, but this comes at an efficiency penalty [48].

The addition of a CO<sub>2</sub> capture unit will probably not affect the ramp rate. Four studies simulated the capture unit (or specific components of it), and showed that these can quickly adjust to a changing flue gas flow whilst maintaining a target capture rate (e.g. 95%) [89–92]. Moreover, A FEED study for a PC power plant with CCS confirms that its ramp rate is probably not affected by the capture unit [64].

### B.3. Start-up time

The start-up time is defined as the time it takes from turn-on to reach the minimum load level. An overview is provided in Table 3. One of the most important start-up processes is heating up the power plant, so the start-up time is highly dependent on whether the unit is in a hot, warm, or cold condition, based on how much time has elapsed since its last shutdown. As with ramping, thermal stress is the main limiting factor for fast start-ups, so measures that increase the ramp speed also shorten the start-up time. In the REPOWERS model runs, hot start-ups are most common, so the hot start-up time is used as the default startup time in the model.

Start-up times of future 3rd generation nuclear power plants are assumed to remain the same as the current state-of-the-art start-up time [13].

The start-up procedure of pulverized coal power plants consists of: (1) establishing boiler circulation, (2) igniting the burners (3) warming up the boiler, during which steam is bypassed to the condenser, and (4) starting the steam turbine, where the third step takes most time [35]. Future improvements include an earlier turbine start with relatively cold steam, and improved start-up procedures [93].

The warm start-up procedure of an IGCC plant consists of (1) Coal and oxygen are fed to the gasifier; (2) Produced syngas is led through treating facilities and flared; (3) Adjusting syngas conditions to NGCC specifications; and (4) Start NGCC or switch from natural gas firing to syngas firing [94]. Start-up times of 6 h and 6–8 h are reported for current IGCC plants [35,94]. The ASU and gasification island are both limiting factors with start-up times of approximately 6 h. Future improvements are dependent on the R&D effort.

The start-up of a NGCC consists of (1) gas turbine start-up, (2) HRSG & steam turbine start-up, and (3) ramp up of the steam turbine. These three steps take around 30, 40 and 20 min, respectively [35]. Three improvements have been suggested to shorten start-up times: using a once-through HRSG, keeping the steam cycle in a hot, operation-ready mode, and optimizing the start-up procedure, for example by using attemperators that allow the gas cycle and steam cycle to be operated independently [95].

Gas turbines can start up rapidly: their start up procedure consists of (1) purging the turbine by revving up without firing, (2)

**Table B.1**

Overview and estimate of cost components of hot startup costs.

	Narrow definition	Broad definition	PC <sup>b</sup> €/MW <sub>installed</sub>	NGCC <sup>c</sup> €/MW <sub>installed</sub>
Maintenance and capital	X	X	76	116
Forced outage <sup>a</sup>		X	36	30
Start-up fuel	X	X	12	9
Auxiliary power		X	6	
Water chemistry costs and support		X	1	
Efficiency loss		X	3	40

<sup>a</sup> A reduction in revenues due to higher forced outage rates.

<sup>b</sup> Hot start costs for a 1 GW PC power plant (€/MW<sub>installed</sub> ± 20%) [98].

<sup>c</sup> Hot start costs for a 120 MW NGCC power plant (€/MW<sub>installed</sub> ± 50%) [99].

**Table B.2**  
Reported start-up costs in literature in €/MW<sub>installed</sub>.

	Lefton <sup>a</sup>	Viswanathan <sup>b</sup>	DENA <sup>c</sup>	Malik <sup>d</sup>	Troy <sup>e</sup>	Swider <sup>f</sup>	KEMA <sup>g</sup>	Lew <sup>h</sup>	Brouwer <sup>i</sup>
PC hot	134			37	29	36		39	53
PC warm	165			52			39	46	82
PC cold	248		211	52				75	111
NGCC hot		194			42	34		27	39
NGCC warm		254						39	49
NGCC cold		373	127					57	78
Cost-definition	Broad	Broad	Narrow	Narrow	Narrow	Narrow	Narrow	Broad	Narrow

<sup>a</sup> Based on a bottom-up analysis. Start costs for a 1GW PC power plant (€/MW<sub>installed</sub> ±20%) [98].

<sup>b</sup> Based on a top-down analysis. Start costs for a 120 MW NGCC power plant (€/MW<sub>installed</sub> ±50%) [99].

<sup>c</sup> Based on figures for power plants from 2005. A start-up fuel price of 9 €/GJ is assumed for either light fuel oil (PC) or natural gas (NGCC) [102].

<sup>d</sup> Based on a function that describes the start-up costs as the boiler start-up costs multiplied by a factor (1-exp(-time off/time constant)) plus the turbine start-up costs. This was determined in an earlier publication of the same author [103].

<sup>e</sup> Based on input data of the WILMAR model, the origin of which is not specified. It is assumed that these costs apply to hot starts, as they are published in a table together with hot start startup times [100].

<sup>f</sup> The source of the figures is not specified, nor the type of start-up cost. For the type of analysis performed it is likely that costs refer to hot start-up costs [104].

<sup>g</sup> Based on in-house data of DNV KEMA, assuming a start-up fuel price of 9 €/GJ [105].

<sup>h</sup> Based on a database of 4000 detailed power plant cost studies. Studies performed for U.S. power plants were categorized by power plant type, and a regression analysis was performed. A higher bound and a lower bound fit were determined. Only figures of the lower bound were published, which show a range of 30% for PC plants ant up to 70% for NGCC plants [101].

<sup>i</sup> Based on an approximation by the authors, where the start-up costs are calculated based on the fuel, CO<sub>2</sub>, and depreciation costs. Auxiliary power is generated by the unit itself. Start-ups are assumed to be performed with natural gas, at a price of 9 €/GJ, a CO<sub>2</sub> price of 10 €/tCO<sub>2</sub> and emissions of 68 kg CO<sub>2</sub>/GJ. The heat requirement of the startup is based that of modern Irish PC and NGCC units [63], which is between the figures reported by other sources [87,102]. Hot/warm/cold heat requirement for PC units is 5/8/11 GJ/MW<sub>installed</sub>, for NGCC units 3/4/7 GJ/MW<sub>installed</sub>, and for GT 1/1/1 GJ/MW<sub>installed</sub>. The depreciation costs are taken from [102].

revving down the turbine, (3) igniting the combustor and (4) warming up the turbine whilst ramping up [96].

The addition of a capture unit could affect the start-up time of power plants, because the stripper of the capture unit will have to warm up. From the moment that steam is available for heating, the start-up of the capture unit may take 45 min ([91], or 2–4 h [35]. This may especially be a problem for NGCC power plants, because steam is not immediately available during its start-up. Options to reduce the capture unit start-up time are (1) initial venting, (2) heat supply by an auxiliary boiler, or (3) storage of rich amines until the stripper is at operating temperature [35,97].

#### B.4. Start-up cost

Startup costs consist of a number of components. Depending on the definition used, only the direct costs are included (the narrow definition) or also indirect costs (the broad definition), as shown in Table B.1. While the direct costs can be easily determined based on the fuel use and the manufacture-defined effect on maintenance and lifetime, the indirect costs are harder to quantify. In the past, Aptech and EPRI have tried to quantify these with a bottom-up and a top-down approach, respectively, but the results were rather power plant specific (Aptech), or had issues with the data quality (EPRI) [98,99]. The range of cost estimates is also sizable, especially for NGCC plants. No universal method currently exists to determine the start-up costs in the broader sense [100]. We distinguish three kinds of start-ups: hot, warm and cold, for power plants that have been switched off for less than 12 h, between 12 and 72 h and more than 72 h, respectively [101].

An overview of reported start-up costs is provided in Table B.2. We base our analysis on the costs reported by Lew et al. (Table 3), because they employ the broad cost definition, provide cost figures for all types of starts, and are based on operational data. These costs are based on the lower range of costs, however, and they might be on the low side: Lefton, Viswanathan and DENA report values that are up to six times the reported values (Table B.2). These high values can be explained by the considerably higher start-up fuel demand (DENA), and the high capital costs. As Troy stated, it is unclear how expensive start-up costs really are [100].

The start-up of a CO<sub>2</sub> capture unit will incur all types of start-up costs presented in Table B.1, but these have not been quantified in

literature. Cohen assessed the sensitivity of the model outcomes to a range of capture unit start-up costs, and found that the capture unit start-up costs only noticeably affected the model outcomes (a 2.5% reduction in profit) if they were equal to the start-up costs of a PC power plant [13]. Considering the limited potential for thermal stress and limited complexity of a capture unit, such high costs seem unlikely, so capture unit start-up costs are not included in the model.

## Appendix C. Description of MARKAL input parameters

### C.1. RES potential

ECN and PBL projected the future deployment of wind and solar PV power in the Netherlands in 2020 and 2030 [17], and their future potential for 2050 [18]. The 2020 and 2030 projections are set as the minimum installed capacities in the model. From 2030 onwards, the future potentials are set as the maximum capacity that the model can deploy. The Baseline is based on their conservative “fixed policy”<sup>3</sup> (Min 3.6 GW onshore wind, 1.7 GW offshore wind, 1.5 GW solar PV in 2020. Max 4 GW onshore wind, 16 GW offshore wind and 27 GW solar PV in 2050). The other scenarios are based on the “intended policy” scenario<sup>2</sup> (Min 6 GW onshore wind, 1.7 GW offshore wind, 1.6 GW solar PV in 2020. Max 8 GW onshore wind, 34 GW offshore wind and 53 GW solar PV in 2050).

### C.2. CHP plant input parameters

Based on a literature review, the current typical state-of-the-art and future techno-economic parameters of CHP generators were determined (Table C.1). Future developments consist of a gradual increase in electrical efficiency whilst keeping fixed heat efficiency, and a decrease in investment and O&M costs. In addition, each unit type was also separately defined as a technology as being equipped with CCS.

<sup>3</sup> These terms translate as “vastgesteld beleid” and “voorgesteld beleid,” which are the scenario names used by ECN in Dutch energy projections [25].

**Table C.1**  
Techno-economic parameters of current and future CHP plants. Sources: [16,42,106–111].

Technology	Scale (MW)	2010 electrical efficiency (%)	$\eta_e$ development per decade (%-pt) <sup>a</sup>	2010 thermal efficiency (%)	$\eta_{th}$ development per decade (%-pt) <sup>a</sup>	Investment cost (€/kW)	Investment development per decade <sup>a</sup>	O&M cost (€/MWh)	O&M development per decade <sup>a</sup>	Capacity factor (%)
Gas engine <sup>b</sup>	2–5	41	+1.7	50	–0.5	589	–7%	7	–3%	51
Combined cycle <sup>b</sup>	125–250	42	+1.3	38	0	880	–3%	6	–3%	91
Gas turbine <sup>b</sup>	25–45	30	+1.6	50	0	961	–6%	5	–3%	91
Fuel cell <sup>c</sup>	0.5–5	42	+1.3	40	0	1715	–7%	14	–3%	51

<sup>a</sup> The development shows the projected cumulative improvement of the techno-economic parameters; e.g. Gas engine electrical efficiency is projected to be 46.1% ( $3 \times 1.7\%$ ) in 2040.

<sup>b</sup> The MARKAL model also considers this unit equipped with CCS, which incurs a 2%-point electric efficiency penalty, and a 13%-point heat efficiency penalty. This increases the investment costs by €1732, €559 and €934/kW for gas engines, combined cycles and gas turbines respectively [108].

<sup>c</sup> The presented parameters are for the year 2020, which is the first year that fuel cell technology is available in the model. The MARKAL model also considers this unit equipped with CCS, which incurs a 2%-point electric efficiency penalty, and a 2%-point heat efficiency penalty, at an increase of 536 €/kW in investment costs [108].

### C.3. Electricity and heat demand

Gross electricity demand in 2011 amounted to 122 TWh/yr, of which 11% was produced and consumed locally. This share did not enter the public power grid, because it was used on site, e.g. at industrial sites and hospitals [112]. Future electricity demand is calculated based on a projected annual increase in electricity demand. For the REPOWERS model, the electricity demand pattern is based on the year 2011 demand pattern of grid electricity [113]. Half of the local electricity generation and consumption is assumed to be base-load (constant through time), and the other half has the same pattern as grid demand [67].

Future heat demand is based on projections by ECN per sector, and a must-run/flexible demand ratio per sector that is based on the present-day situation [114,115]. Annual heat demand is divided between seasons for flexible demand [29,116], and agricultural demand [117].

## Appendix D. Description of REPOWERS input parameters

### D.1. Load and renewable electricity production patterns

Load and wind/solar PV generation patterns are based on historical time series that are adjusted for future developments, as recommended by [8]. Time series from the year 2011 are used, because its annual wind power production is close to the multi-year average (96% of the 10-year average, which has a variation of  $\pm 15\%$ ) [118].

Wind power production is calculated based on wind speed measurements, as described in [119]. First, three offshore wind turbine areas and seven onshore areas were defined (Table D.1), for which historical hourly wind speed measurements were obtained [120]. Second, the reported wind speed measurements for a height of 10 m were converted to a hub height of 80–100 m using the log law reported by Lackner [121]. Third, the electricity production is determined using two wind-speed/power-output curves: one for onshore [122], and one for offshore turbines [122,123]. The resulting capacity factors are 28% for onshore and 47% for offshore wind. The offshore capacity factor is in line with the projected factor for the mid-2020s of 45% by Heptonstall et al. [124].

The hourly solar PV power production pattern is constructed by fitting the total annual Dutch solar PV production in 2011 on the hourly average insolation pattern of 11 weather measurement locations across the Netherlands [120].

### D.2. Reserve size

Three types of reserves are distinguished in this study: spinning, sub-hourly standing reserves and hourly standing reserves. The reserve size is determined by the inherent uncertainty of the prediction of both load and the generation by intermittent renewable sources. Based on previous findings, reserve sizes are expressed as a percentage of load and intermittent electricity production. For each reserve type, only the provision of reserve capacity is modeled, not the actual generation of reserves. Only upward reserves are presented, because sufficient downwards reserves are

**Table D.1**  
Regions considered for calculation of wind power production.

Area	Share in 2030 and 2050 <sup>a</sup>	KNMI measuring stations <sup>c</sup>
<i>Offshore</i>		
Off the Noord Holland coast	43% of offshore <sup>b</sup>	K13-A, K14-FA-1C, Hoorn-A
Off the Zuid Holland coast	43% of offshore <sup>b</sup>	Euro Platform, P11-B, Goeree LE
North of the Netherlands	14% of offshore <sup>b</sup>	AWG-1, L9-FF-1
<i>Onshore<sup>d</sup></i>		
Groningen	11% of onshore <sup>c</sup>	Lauwersoog, Nieuw Beerta
Friesland	18% of onshore <sup>c</sup>	Leeuwarden, Stavoren
Flevoland	31% of onshore <sup>c</sup>	Marknesse, Lelystad
Noord Holland	17% of onshore <sup>c</sup>	De Kooy, Schiphol
Zuid Holland	8% of onshore <sup>c</sup>	Rotterdam, Hoek van Holland
Zeeland	11% of onshore <sup>c</sup>	Vlissingen, Wilhelminadorp
Noord-Brabant	3% of onshore <sup>b</sup>	Woensdrecht, Gilze-rijen

<sup>a</sup> The installed capacities per scenario are shown in Fig. 3.

<sup>b</sup> Division of offshore capacity is based on the 2030 projections of TenneT and the Basic 2020 scenario of Gibescu et al. [119,125].

<sup>c</sup> Division of onshore capacity is based on the current Dutch distribution of onshore wind energy [118].

<sup>d</sup> Only 7 provinces are included, as 5 remaining provinces only make up 2.5% of the total installed capacity. This share will only slightly increase in the future up to 12%.

<sup>e</sup> The hourly production is calculated based on the average hourly wind speed of the measuring stations per area.

available at all times by ramping down units and curtailing wind power.

Spinning reserves consist of frequency and regulating reserves that have lead times of <15 min and thus can only be delivered by online units. Units can supply up to 10% of their capacity as spinning reserves, to ensure that not all spinning reserves are delivered by a couple of units. Wind integration studies show that the effect of higher wind penetration levels on frequency reserves (primary control reserve with an activation time smaller than 30 s) is limited, increasing the reserve size by up to 0.8% of installed wind capacity [8]. The increase in regulating reserves (secondary control reserve with an activation time up to 15 min) resulting from wind power is 0–3% of installed wind power capacity [8]. In this analysis, spinning reserves have a size equal to 1% of load, plus a maximum of 2.5% of installed wind and solar PV capacity [8,126]. The reserves are sized dynamically, depending on the expected intermittent power production and are typically around 400 MW ( $\pm 200$  MW).

Standing reserves are assumed to have lead times of >15 min, and comprise sub-hourly and hourly reserves. Upwards standing reserves can be delivered by offline units as long as their start-up times are shorter than the reserves' lead time. Downward reserves can be delivered by online units and by curtailing intermittent generators. The size of both upward and downward sub-hourly

standing reserves is 800 MW, plus 6% of generating intermittent capacity, and the size of hourly standing reserves is 22% of generating intermittent capacity [127]. Units can provide multiple types of reserves, but every MW of reserve capacity can only be designated to one type of reserve.

### D.3. Exchange with neighboring countries

The power sectors of neighboring countries are modeled based on cost-supply curve projections, in which 16 types of generators are distinguished. Hence, the model does not account for flexibility constraints abroad. Residual demand patterns were constructed by deducting wind and solar PV electricity generation from the projected load per country for every hour. The electricity price of each country is determined by the intersection of the cost-supply curve and the sum of the residual load plus exports. The specifications of foreign power systems are based on a number of sources (Table D.2).

Interconnection capacity is based on the current installed interconnection capacity, which is extended based on short-term and long-term projections (Table D.3) [125,139,140]. In the Baseline scenario, only current expansion plans to Germany are included. In the Stalemate scenario, the interconnection capacity that is currently being planned is also included. In the Global Union and Fuel

**Table D.2**

Description of the representation of the power sector of neighboring countries.

Input	Description	Sources
Load	Historical hourly load of 2011, with the same annual increase as the Netherlands	[128]
Electricity generation capacity per technology	Projections of the PRIMES model, which were adjusted to match national projections <sup>a</sup>	[129–132]
Specifications of thermal power generators	Projected specifications, corrected for a reduction in efficiency <sup>b</sup>	Table 5
Wind power	Based on hourly production of 2011 (DE, DK, UK) or wind measurements (BE) <sup>c</sup>	[120,133–135]
Solar power	Based on hourly production of 2011 (DE, DK) or insolation measurements (UK, BE) <sup>c,d</sup>	[120,136,137]

<sup>a</sup> The 2012 PRIMES' Baseline and Reference scenarios were adjusted to reflect the current national goals, as reported in national reports. For example, the PRIMES outcomes were corrected for projected shares of renewables, nuclear and CCS-capacity per country. A summary of installed capacities is provided in Tables D.4–D.7.

<sup>b</sup> The efficiency is reduced by ~1 percentage-point for coal-fired, and ~5 percentage-points for natural gas fired capacity to account for part-load operation (Fig. 2), and 0.8 (coal-fired)/0.3 (natural gas fired) percentage-points to reflect that mostly draft cooling is used in neighboring countries, rather than once-through cooling [87,138].

<sup>c</sup> No renewable production patterns were available for Belgium for the year 2011, so the RES generation patterns are based on the closest proxy: measurements from the south of the Netherlands.

<sup>d</sup> No Danish solar PV generation pattern is available, so it is based on the closest proxy: solar PV generation in the North of Germany.

**Table D.3**

Current NTC capacity and projected interconnection capacity expansions with neighboring countries.

	Current capacity (MW)	Future expansion of interconnection capacity (year)		
		Baseline (MW)	Stalemate (MW)	Global Union and Fuel Shift (MW)
Germany	3700 <sup>a</sup>	1300 (2020)	1300 (2020)	1300 (2020)
Denmark	0	X	700 (2030)	700 (2030) and 700 (2040)
U.K.	1000	X	X	1000 (2030)
Belgium	2300 <sup>a</sup>	X	X	1400 (2040)

<sup>a</sup> Average of both flow directions.

**Table D.4**

Installed capacity in Germany per scenario (GW).

	Baseline 2030	Baseline 2050	Impasse 2030	Impasse 2050	Global Union, Fuel Shift 2030	Global Union, Fuel Shift 2050
Nuclear	0	0	0	0	0	0
Hydro	5	5	5	5	5	5
Onshore wind	48	48	52	66	86	94
Offshore wind	11	11	24	29	24	28
Solar PV	56	56	63	65	63	74
Solid fuels	54	73	37	14	18	0
Solid fuels + CCS	0	0	0	9	19	19
NGCC	30	51	49	76	28	0
NGCC + CCS	0	0	0	0	32	76
Biomass	9	10	9	11	9	11

**Table D.5**  
Installed capacity in Belgium per scenario (GW).

	Baseline 2030	Baseline 2050	Impasse 2030	Impasse 2050	Global Union, Fuel Shift 2030	Global Union, Fuel Shift 2050
Nuclear	0	0	0	0	0	0
Hydro	0	0	0	0	0	0
Onshore wind	3	4	4	5	5	8
Offshore wind	1	1	2	5	3	6
Solar PV	3	5	4	7	6	10
Solid fuels	5	7	0	0	0	0
Solid fuels + CCS	0	0	0	0	0	0
NGCC	11	14	14	16	14	2
NGCC + CCS	0	0	0	7	0	15
Biomass	1	2	2	2	2	2

**Table D.6**  
Installed capacity in the United Kingdom per scenario (GW).

	Baseline 2030	Baseline 2050	Impasse 2030	Impasse 2050	Global Union, Fuel Shift 2030	Global Union, Fuel Shift 2050
Nuclear	11	14	8	10	16	19
Hydro	2	2	2	2	2	2
Onshore wind	18	27	16	21	13	13
Offshore wind	8	9	15	20	37	37
Solar PV	4	4	5	5	6	7
Solid fuels	9	8	0	0	0	0
Solid fuels + CCS	0	0	5	0	5	0
NGCC	52	57	47	49	50	16
NGCC + CCS	0	0	6	12	7	66
Biomass	3	4	3	4	3	4

**Table D.7**  
Installed capacity in Denmark per scenario (GW).

	Baseline 2030	Baseline 2050	Impasse 2030	Impasse 2050	Global Union, Fuel Shift 2030	Global Union, Fuel Shift 2050
Nuclear	0	0	0	0	0	0
Hydro	0	0	0	0	0	0
Onshore wind	7	7	7	10	7	10
Offshore wind	2	2	2	2	3	5
Solar PV	1	1	1	1	1	1
Solid fuels	3	2	1	0	1	0
Solid fuels + CCS	0	0	1	1	0	0
NGCC	5	5	5	5	2	0
NGCC + CCS	0	0	0	0	5	6
Biomass	1	2	1	2	1	2

Shift scenarios, all capacity additions that are suggested in the Tradewind and TenneT studies are also included. It is assumed that 75% of the net transfer capacity is available during situations of large interconnection flows, as a result of loop flows and (forced) outages [141]. A transmission charge of 5 €/MWh is assumed, based on historical values [142].

## References

- [1] EC. A roadmap for moving to a competitive low carbon economy in 2050. Brussels: European Commission; 2011.
- [2] EC. A policy framework for climate and energy in the period from 2020 to 2030 – COM(2014) 15. Brussels: European Commission; 2014.
- [3] ECF. Roadmap 2050. Technical analysis, vol. 1. Brussels: European Climate Foundation; 2010.
- [4] EC. Energy roadmap 2050 – COM(2011) 885/2. Brussels: European Commission; 2011.
- [5] OECD/IEA. World energy outlook 2012. Paris, France: International Energy Agency; 2012.
- [6] Eurelectric. Flexible generation: backing up renewables. Report D/2011/12.105/47. Brussels; 2011.
- [7] IEA. Energy technology perspectives 2012. Paris: International Energy Agency; 2012.
- [8] Brouwer AS, van den Broek M, Seebregts A, Faaij A. Impacts of large-scale electricity generation by intermittent renewable energy sources on the electricity system, and how these can be modeled. *Renew Sustain Energy Rev* 2014;33:443–66.
- [9] Sensfuss F, Ragwitz M, Genoese M. The merit-order effect: a detailed analysis of the price effect of renewable electricity generation on spot market prices in Germany. Karlsruhe; 2007.
- [10] IPCC. IPCC Special Report on Renewable Energy Sources and Climate Change Mitigation. Cambridge: Cambridge University Press; 2011.
- [11] Bertsch J, Growitsch C, Lorenczik S, Nagl S. Flexibility Options in European Electricity Markets in High RES-E Scenarios – Study on Behalf of the International Energy Agency. Cologne, Germany: Energiewirtschaftliches Institut an Der Universität Zu Köln (EWI); 2012.
- [12] McCoy S, Bertsch J, Growitsch C, Lorenczik S, Nagl S, Volk D, et al. The role of CCS in power systems with high levels of renewables penetration; 2013.
- [13] Cohen S. A techno-economic plant- and grid-level assessment of flexible CO<sub>2</sub> capture. PhD dissertation. The University of Texas at Austin; 2012.
- [14] Hundt M, Barth R, Sun N, Brand H, Voß A. Herausforderungen eines Elektrizitätsversorgungssystems mit hohen Anteilen erneuerbarer Energien. Stuttgart: Institut Für Energiewirtschaft Und Rationelle Energieanwendung, Universität Stuttgart; 2010.
- [15] Seebregts A, van Deurzen J. Carbon capture & storage in power generation and wind energy: flexibility and reliability issues in scenarios for Northwest Europe. *Energy Procedia* 2011;4:5877–88.
- [16] van den Broek M, Veenendaal P, Koutstaal P, Turkenburg W, Faaij A. Impact of international climate policies on CO<sub>2</sub> capture and storage deployment: illustrated in the Dutch energy system. *Energy Policy* 2011;39:2000–19.
- [17] Verdonk M, Wetzels W. Referentieraming Energie en Emissies: Actualisatie 2012. PBL and ECN; 2012.
- [18] PBL/ECN. Naar een schone economie in 2050: routes verkend. Den Haag; 2011.
- [19] Metz B, Davidson OR, Bosch PR, Dave R, Meyer LA, editors. Climate Change 2007: Mitigation. Contribution of Working Group III to the Fourth Assessment Report of the Intergovernmental Panel on Climate

- Change. Cambridge, United Kingdom and New York, NY, USA: Cambridge University Press; 2007.
- [20] Eurostat. ECU/EUR exchange rates versus national currencies; 2013.
- [21] IHS. IHS CERA Power Capital Costs Index (PCCI). Englewood, Colorado; 2013. <<http://www.ihs.com/info/cera/ihsindexes/index.aspx>> [accessed 12.02.15].
- [22] ZEP. The costs of CO<sub>2</sub> capture, transport and storage – post-demonstration CCS in the EU. Zero Emission Platform, Brussels; 2011.
- [23] Batidzirai B, Hilst F Van Der, Meerman H, Junginger MH, Faaij APC. Optimization potential of biomass supply chains with torrefaction technology. *Biofuels, Bioprod Biorefin* 2013;5–7.
- [24] De Wit M, Faaij A. European biomass resource potential and costs. *Biomass Bioenergy* 2010;34:188–202.
- [25] Sikkema R, Steiner M, Junginger M, Hiegl W, Hansen MT, Faaij A. The European wood pellet markets: current status and prospects for 2020. *Biofuels, Bioprod Biorefin* 2011;5:250–78.
- [26] Seebregts A, Goldstein G, Smekens K. Energy/environmental modeling with the MARKAL family of models. *Opt Res Proc* 2001;2001(2002):75–82.
- [27] IEA ETSAP. Description of MARKAL; 2014. <<http://www.iea-etsap.org/web/Markal.asp>> [accessed 12.02.15].
- [28] Vliet van O, Broek van den M, Turkenburg W, Faaij A. Combining hybrid cars and synthetic fuels with electricity generation and carbon capture and storage. *Energy Policy* 2011;39:248–68.
- [29] Brouwer AS, Kuramochi T, van den Broek M, Faaij A. Fulfilling the electricity demand of electric vehicles in the long term future: an evaluation of centralized and decentralized power supply systems. *Appl Energy* 2013;107:33–51.
- [30] ECN. Tools – modelling systems – REPOWERS; 2012. <<http://www.ecn.nl/units/ps/models-and-tools/repowers/>> [accessed 14.02.14].
- [31] Deane JP, Chiodi A, Gargiulo M, Ó Gallachóir BP. Soft-linking of a power systems model to an energy systems model. *Energy* 2012;42:303–12.
- [32] Vuorinen A. Planning of optimal power systems. Espoo, Finland: Oekoenergo Oy; 2009.
- [33] Jeschke R, Henning B, Schreier W. Flexibility through highly-efficient technology. *VGB PowerTech* 2012;5.
- [34] Dijkema G, Lukso Z, Verkooijen A, de Vries L, Weijnen M. De regelbaarheid van elektriciteitscentrales, vol. 80. Delft, The Netherlands: Delft University; 2009.
- [35] IEAGHG. Operating flexibility of power plants with CCS, 2012/6. Cheltenham, UK; 2012.
- [36] Klobasa M, Erge T, Wille-hausmann B. Integration von Windenergie in ein zukünftiges Energie- system unterstützt durch Lastmanagement. Report 0327577. Fraunhofer Institut für System- Und Innovationsforschung. Karlsruhe; 2009.
- [37] Balling L. Flexible future for combined cycle. *Mod Power Syst* 2010;61–5.
- [38] Isles J. Prospects for lower cost and more efficient IGCC power. *Gas Turbine World* 2012;4.
- [39] Stevens M, Hummel F, Jakoby R, Eppler V, Ruchti C, Power A. Increased operational flexibility from the latest GT26 (2011) upgrade. *PowerGen Eur* 2012. Cologne, Germany: PennWell Corporation; 2012. p. 20.
- [40] NETL. Impact of load following on power plant cost and performance: literature review and industry interviews; 2012.
- [41] Lew D, Brinkman G, Ibanez E, Florita A, Heaney M, Hodge B, et al. The western wind and solar integration study phase 2. NREL/TP-5500-55588. Golden, Colorado; 2013.
- [42] Kuramochi T, Faaij A, Ramírez A, Turkenburg W. Prospects for cost-effective post-combustion CO<sub>2</sub> capture from industrial CHPs. *Int J Greenh Gas Control* 2010;4:511–24.
- [43] Linnenberg S, Oexmann J, Kather A. Design considerations of post-combustion post combustion CO<sub>2</sub> capture process during part load operation of coal-fired power plants. 12th Int post combust capture netw meet; 2009.
- [44] Sakai K, Morita S, Sato T. State-of-the-art technologies for the 1000-MW 24.5-MPa/600 °C/600 °C coal-fired boiler. *Hitachi Rev* 1999;48:273–6.
- [45] OECD/IEA. Power generation from coal – measuring and reporting efficiency performance and CO<sub>2</sub> emissions. Paris: International Energy Agency; 2010.
- [46] Roeder V, Hasenbein C, Kather A. Evaluation and comparison of the part load behaviour of the CO<sub>2</sub> capture technologies oxyfuel and post-combustion. *Energy Procedia* 2013;37:2420–31.
- [47] Meerman JC, Ramírez A, Turkenburg WC, Faaij APC. Performance of simulated flexible integrated gasification polygeneration facilities. Part A: A technical-energetic assessment. *Renew Sustain Energy Rev* 2011;15:2563–87.
- [48] Breeze P. Efficiency versus flexibility: advances in gas turbine technology. *Power Eng Int* 2011.
- [49] Probert T. Fast starts and flexibility – let the gas turbine battle commence. *Power Eng Int* 2011.
- [50] IEAGHG. CO<sub>2</sub> capture at gas fired power plants, 2012/8. Cheltenham, UK; 2012.
- [51] MITEL. MIT energy initiative symposium on managing large-scale penetration of intermittent renewables. April 20, 2011. Cambridge, Massachusetts; 2011.
- [52] Kim T. Comparative analysis on the part load performance of combined cycle plants considering design performance and power control strategy. *Energy* 2004;29:71–85.
- [53] Bruynooghe C, Eriksson A, Fulli G. Load-following operating mode at Nuclear Power Plants (NPPs) and incidence on Operation and Maintenance (O & M) costs. Compatibility with wind power variability. Luxembourg; 2010.
- [54] GCCSI. Economic assessment carbon capture and storage technologies – 2011 update. Canberra, Australia: Global CCS Institute; 2011.
- [55] OECD/IEA. Projected costs of generating electricity 2010. Paris: OECD Publishing; 2010.
- [56] EPRI. Program on technology innovation: integrated generation technology options. Palo Alto, California, US; 2011.
- [57] NETL. Current and future technologies for power generation with post-combustion carbon capture final report; 2012.
- [58] NETL. Cost and performance baseline for fossil energy plants. Bituminous coal and natural gas to electricity, vol. 1; 2010.
- [59] Knoope MMJ, Meerman JC, Ramírez A, Faaij APC. Future technological and economic performance of IGCC and FT production facilities with and without CO<sub>2</sub> capture: combining component based learning curve and bottom-up analysis. *Int J Greenh Gas Control* 2013.
- [60] NERC. Generating unit statistical brochure – 2006–2010 generating availability data system (GADS); 2011.
- [61] ENTSO-E. System adequacy forecast 2011–2025. Brussels; 2011.
- [62] EEX Transparency Platform. Unscheduled non-usabilities of generating units of ≥100 MW. Leipzig, Germany; 2013. <<http://www.transparency.eex.com/en/>> [accessed 12.02.15].
- [63] Meibom P, Barth R, Brand H, Hasche B, Swider D, Ravn H, et al. All islands grid study, workstream 2B. Roskilde: Risoe National Laboratory; 2008.
- [64] E.ON. Kingsnorth carbon dioxide capture and storage demonstration project FEED study; 2011.
- [65] Klinkby L, Nielsen CM, Krogh E, Smith IE, Palm B, Bernstone C. Simulating rapidly fluctuating CO<sub>2</sub> flow into the Vedsted CO<sub>2</sub> pipeline, injection well and reservoir. *Energy Procedia* 2011;4:4291–8.
- [66] Veen W, Moldovan N, Benz E, Hewicker C. Nut en Noodzaak van Grootschalige Energieopslag in Nederland. Arnhem: KEMA; 2010.
- [67] Ummels B. Power system operation with large-scale wind power in liberalised environments. PhD Dissertation. Delft University; 2009.
- [68] European Commission. Energy union package – a framework strategy for a resilient energy union with a forward-looking climate change policy. COM(2015) 80 Final. Brussels, Belgium; 2015.
- [69] Williams JH, DeBenedictis A, Ghanadan R, Mahone A, Moore J, Morrow WR, et al. The technology path to deep greenhouse gas emissions cuts by 2050: the pivotal role of electricity. *Science* 2012;335:53–9.
- [70] IEAGHG. Potential for biomass and carbon capture and storage 2011/06. Cheltenham; 2011.
- [71] ZEP. Biomass with CO<sub>2</sub> capture and storage (Bio-CCS) the way forward for Europe. Brussels; 2013.
- [72] Luckow P, Wise MA, Dooley JJ, Kim SH. Large-scale utilization of biomass energy and carbon dioxide capture and storage in the transport and electricity sectors under stringent CO<sub>2</sub> concentration limit scenarios. *Int J Greenh Gas Control* 2010;4:865–77.
- [73] Smeets E, Faaij A, Lewandowski I, Turkenburg W. A bottom-up assessment and review of global bio-energy potentials to 2050. *Prog Energy Combust Sci* 2007;33:56–106.
- [74] Dornburg V, van Vuuren D, van de Ven G, Langeveld H, Meeusen M, Banse M, et al. Bioenergy revisited: key factors in global potentials of bioenergy. *Energy Environ Sci* 2010;3:253.
- [75] Virmani S, Adrian EC, Imhof K, Mukherjee S. Implementation of a Lagrangian relaxation based unit commitment problem. *IEEE Trans Power Syst* 1989;4:1373–80.
- [76] Wood W. Spinning reserve constrained static and dynamic economic dispatch. *IEEE Trans Power Appar Syst* 1982;PAS-101:381–8.
- [77] Wang SJ, Shahidehpour SM, Kirschen DS, Mokhtari S, Irisarri GD. Short-term generation scheduling with transmission and environmental constraints using an augmented Lagrangian relaxation. *IEEE Trans Power Syst* 1995;10:1294–301.
- [78] Saygin D, Patel MK, Worrell E, Tam C, Gielen DJ. Potential of best practice technology to improve energy efficiency in the global chemical and petrochemical sector. *Energy* 2011;36:5779–90.
- [79] Boer-Meulman P, van der Burgt JJA, Hafkamp PJM, Hunik R, Kokmeijer E, Kolokathis C, et al. Effect of scenarios and alternatives for electric vehicles and heat pump implementation on grid reliability, sustainability and socio-economy – WP 3 Report nr. 10-4193. Den Haag; 2010.
- [80] OECD/NEA. Technical and economic aspects of load following with nuclear power plants. Issy-Les-Moulineaux, France; 2011.
- [81] Kral R, Wittchow E. Steam generators for the next generation of power plants. Aspects of design and operating performance. *VGB PowerTech* 1999;12.
- [82] Richardson M, Kidera Y, Shimogori Y. Supercritical boiler technology matures. New York, USA: Hitachi America; 2004.
- [83] Vogt J, Schaaf T, Mohr W, Helbig K. Flexibility improvement of the steam turbine of conventional or CCPP. *PowerGen Eur* 2013. Vienna: PennWell Corporation; 2013. p. 21.
- [84] EU. DIRECTIVE 2001/80/EC on the limitation of emissions of certain pollutants into the air from large combustion plants, vol. 30. Brussels: European Union; 2002.
- [85] Fischer WJ, Nag P. H-class high performance siemens gas turbine SGT-8000H series. *Power-gen int* 2011. Las Vegas, U.S.: PennWell Corporation; 2011. p. 10.
- [86] Black & Veatch. Cost report – cost and performance data for power generation technologies; 2012.
- [87] Spliethoff H. *Power generation from solid fuels*. Berlin, Heidelberg: Springer; 2010.

- [88] Cziesla F, Bewerunge J, Senzel A. Lünen – state-of-the-art ultra supercritical steam power plant under construction. *PowerGen Eur* 2009;2009:21.
- [89] Brasington RD, Herzog HJ. Integration and operation of post-combustion capture system on coal-fired power generation: load following and peak power. MIT; 2012.
- [90] Lawal A, Wang M, Stephenson P, Yeung H. Dynamic modelling of CO<sub>2</sub> absorption for post combustion capture in coal-fired power plants. *Fuel* 2009;88:2455–62.
- [91] Kvamsdal HM, Jakobsen JP, Hoff Ka. Dynamic modeling and simulation of a CO<sub>2</sub> absorber column for post-combustion CO<sub>2</sub> capture. *Chem Eng Process: Process Intensif* 2009;48:135–44.
- [92] Ziaii S, Cohen S, Rochelle GT, Edgar TF, Webber ME. Dynamic operation of amine scrubbing in response to electricity demand and pricing. *Energy Procedia* 2009;1:4047–53.
- [93] Quinkertz R, Ulma A, Gobrecht E, Wechsung M. USC steam turbine technology for maximum efficiency and operational flexibility. *PowerGen Asia* 2008 2008:17.
- [94] Black & Veatch. Supplementary study of generating alternatives for Deerhaven generating station – Project Number 137196. Jacksonville, USA; 2004.
- [95] Balling L. Fast cycling and rapid start-up: new generation of plants. *Mod Power Syst* 2011:35–41.
- [96] GE Energy. LS2100 static starter product description. Salem, USA; 2002.
- [97] Chalmers H. Flexible operation of coal-fired power plants with post-combustion capture of carbon dioxide. Degree of Doctor of Philosophy in Environmental Strategy Centre of Environmental Strategy Faculty of Engineering and Physical Sciences. University of Surrey; 2010.
- [98] Lefton S, Hilleman D. The cost of cycling coal fired power plants. *Coal Power Mag Winter* 2006.
- [99] Viswanathan V, Gray D. Damage to power plants due to cycling. Palo Alto, USA: EPRI; 2001.
- [100] Troy N, Denny E, O'Malley M. The relationship between base-load generation, start-up costs and generation cycling. 28th USAEE/IAEE North Am conf, New Orleans, US, International Association for Energy Economics; 2008. p. 1–15.
- [101] Lew D, Brinkman G, Kumar N, Besuner P, Agan D, Lefton S. Impacts of wind and solar on fossil-fueled generators preprint. IEEE power energy soc gen meet, San Diego, California; 2012.
- [102] Deutschen Energie-Agentur GmbH. *Energiewirtschaftliche Planung für die Netzintegration von Windenergie in Deutschland an Land und Offshore bis zum Jahr 2020*. Cologne: Deutschen Energie-Agentur GmbH; 2005.
- [103] Malik AS, Cory BJ. Integrated resource planning with consideration of dynamic costs of thermal units. *Electr Power Syst Res* 1999;51:123–30.
- [104] Swider DJ, Weber C. An electricity market model to estimate the marginal value of wind in an adapting system. 2006 IEEE power eng soc gen meet; 2006. 8 p.
- [105] Wijk van der P, Brouwer AS, van den Broek M, Slot T, Stienstra G, van der Veen W, et al. Benefits of coal-fired power plant with flexible CCS in a future northwest European power system with large scale wind power. *Int J Greenh Gas Control* 2014;28:216–33.
- [106] Kuramochi T, Ramírez A, Turkenburg W, Faaij A. Techno-economic prospects for CO<sub>2</sub> capture from distributed energy systems. *Renew Sustain Energy Rev* 2013;19:328–47.
- [107] Kuramochi T, Turkenburg W, Faaij A. Competitiveness of CO<sub>2</sub> capture from an industrial solid oxide fuel cell combined heat and power system in the early stage of market introduction. *Fuel* 2011;90:958–73.
- [108] Telgte P Ter. Prospects of capture and geological storage of CO<sub>2</sub> from CHP plants in the Netherlands. MSc Thesis. Utrecht, The Netherlands; 2012.
- [109] Lako P. IEA ETSAP – technology brief E04 – combined heat and power; 2010.
- [110] Hers JS, Wetzels W, Seebregts AJ, Welle A Van Der. Onrendabele top berekeningen voor nieuw WKK-vermogen 2008. Petten; 2008.
- [111] IEAGHG. CO<sub>2</sub> capture from medium scale combustion – 2007/7. Cheltenham, UK; 2007.
- [112] CBS. Elektriciteitsbalans; aanbod en verbruik. Heerlen, The Netherlands; 2013. <<http://statline.cbs.nl/StatWeb/publication/?PA=00377>> [accessed 12.02.12].
- [113] TenneT. Exporteer data Consumptie. Arnhem, The Netherlands; 2013. <<http://energieinfo.tennet.org/>> [accessed 12.02.15].
- [114] ECN. MONITweb. Petten, The Netherlands: Energy Research Centre of the Netherlands; 2014. <<http://monitweb.energie.nl/asp>> [accessed 12.02.15].
- [115] ECN. WKK Basislijst (confidential). Petten, The Netherlands: Energy Research Centre of The Netherlands; 2013.
- [116] NEN. NPR 2917. Delft: NEN; 2010. <<http://www.nen.nl/web/Normshop/Norm/NPR-2917A22010-v.2.2-NI.htm>> [accessed 12.02.15].
- [117] Cogen Projects. WKK in Het Nieuwe Telen WKK in Het Nieuwe Telen Een analyse van de rentabiliteit; 2010.
- [118] CBS. Windenergie; elektriciteitsproductie, capaciteit en windaanbod per maand; 2015. <<http://statline.cbs.nl/Statweb/publication/?DM=SLNL&PA=70802NED&D1=0,5-6&D2=a&D3=16,33,50,67,84,101,118,135,152,169,186,203,220&HDR=T,G1&STB=G2&VW=T>> [accessed 17.06.15].
- [119] Gibescu M, Brand AJ, Kling WL. Estimation of variability and predictability of large-scale wind energy in The Netherlands. *Wind energy* 2009;12(3): 241–60.
- [120] KNMI. Uurgegevens van het weer in Nederland. De Bilt, The Netherlands; 2013. <<http://www.knmi.nl/klimatologie/uurgegevens/>> [accessed 12.02.15].
- [121] Lackner Ma, Rogers AL, Manwell JF, McGowan JG. A new method for improved hub height mean wind speed estimates using short-term hub height data. *Renew Energy* 2010;35:2340–7.
- [122] McLean JR. Equivalent wind power curves – Tradewind WP 2.6; 2008.
- [123] EC. IRENE-40 Annex 4. 2 – Large scale integration of intermittent electricity generation. Brussels; 2011.
- [124] Heptonstall P, Gross R, Greenacre P, Cockerill T. The cost of offshore wind: understanding the past and projecting the future. *Energy Policy* 2012;41:815–21.
- [125] TenneT. Visie2030. TenneT TSO. Arnhem, The Netherlands; 2010.
- [126] NERC. Balancing and frequency control. NERC Resources Subcommittee. Princeton, NJ; 2011.
- [127] De Boer WW, Van der Veen W. Balancing with 6000 MW off shore wind energy in The Netherlands; an analysis of the flexibility of production. 8th Int work large-scale integr wind power into power syst as well as Transm. Networks Offshore Wind Farms, Bremen; 2009.
- [128] ENTSO-E. Hourly load values of ENTSO-E countries. Brussels; 2015. <<https://www.entsoe.eu/data/data-Portal/consumption/>> [accessed 17.06.15].
- [129] National Grid. UK future energy scenarios. Warwick, UK; 2011.
- [130] Feix O, Obermann R, Strecker M, Brötel A. Netzentwicklungsplan Strom 2013; 2013.
- [131] Dufresne L, Fauconnier M, Ruyck J de. Groep gemix – Welke is de ideale energiemix voor België tegen 2020 en 2030 ? Brussels; 2012.
- [132] EC. EU Energy, Transport and GHG emissions trends to 2050. Reference scenario 2013. Brussels: European Commission; 2013.
- [133] EEX Transparency Platform. Actual wind power generation. Leipzig, Germany; 2014. <<http://www.transparency.eex.com/en/>> [accessed 12.02.15].
- [134] Energinet.dk. Wind power production in Denmark; 2013.
- [135] Elexon. Historic generation by fuel type. London; 2013. <[www.elexonportal.co.uk/historicgenerationbyfueltype](http://www.elexonportal.co.uk/historicgenerationbyfueltype)> [accessed 12.02.15].
- [136] UK Meteorological Office. Met Office Integrated Data Archive System (MIDAS) land and marine surface stations data (1853-current); 2014.
- [137] EEX Transparency Platform. Actual solar power generation. Leipzig, Germany; 2014. <<http://www.transparency.eex.com/en/>> [accessed 12.02.15].
- [138] EPA. Technical development document for the final regulations addressing cooling water intake structures for new facilities. Report EPA-821-R-01-036. Washington D.C.: United States Environmental Protection Agency; 2001.
- [139] Korpås M, Warland L, Tande JO, Uhlen K, Boer J, Groeman F, et al. TradeWind WP6.1 – Assessment of increasing capacity on selected transmission corridors; 2008.
- [140] ENTSO-E. 10-Year network development plan 2012. Brussels; 2012.
- [141] TenneT. Rapport monitoring Leveringszekerheid 2011–2027 – RGE2012-115. Arnhem; 2012.
- [142] TenneT. Auction results. Arnhem, The Netherlands; 2013. <<http://energieinfo.tennet.org/Connection/AuctionResultsYearCountry.aspx>> [accessed 12.02.15].
- [143] UNFCC. GHG data queries. <<http://unfccc.int/di/FlexibleQueries/Event.do?event=go>> [accessed 04.02.15]. Bonn, Germany: UNFCC; 2014.